

NFRC Product Certification Authorization Report



Manufacturer: SourcePoint Doors and Windows LLC
Street: 4363 Northeast Expressway
City/State/Zip: Atlanta, Georgia
Product Series: 87 Series Casement Window
Product Type: CSSV
Air Leakage: ≤ 0.3
Simulation Lab: SFTL
Sim. Report #: MED-6468a
Sim. Report Date: 04/11/2026
Initial Cert. Date: 06/04/2026
Re-Certification Date:
Revised Date: 01/01/1970
Print Date: 10/06/2026
Test Date: 03/14/2026
Expiration Date: 03/14/2031

CPD Number: SUU-M-11						IA: National Accreditation And Management Institute										
Status	Product Num.	Manufacturer Code	Frame/ Sash	Glaz Lyrs	Low-E (Surface)	Gap Width(s)	Spacer	Gap Fill	Grids	Dividers	Tint	U-Factor	SHGC	VT	Cond. Res	
	00001-00001	6 X179(2)-6 X179(4)-6 X189(5)-13ARG90	AT/AT	3	0.048(2), 0.048(4), 0.18(5)	0.491,0.491	TS-D	Fill 1: ARG (90),Fill 2: ARG (90)	N		CL	0.28	0.15	0.23	67	
	00002-00001	6 X179(2)-6 EG41(4)-6 X189(5)-13ARG90	AT/AT	3	0.048(2), 0.103(4), 0.18(5)	0.491,0.491	TS-D	Fill 1: ARG (90),Fill 2: ARG (90)	N		CL	0.28	0.13	0.14	67	
	00003-00001	6 EG41(2)-6 EG41(4)-6 X189(5)-13ARG90	AT/AT	3	0.103(2), 0.103(4), 0.18(5)	0.491,0.491	TS-D	Fill 1: ARG (90),Fill 2: ARG (90)	N		CL	0.28	0.10	0.08	67	
	00004-00001	6 X179(2)-6 X179(4)-6 EG41(5)-13ARG90	AT/AT	3	0.048(2), 0.048(4), 0.103(5)	0.491,0.491	TS-D	Fill 1: ARG (90),Fill 2: ARG (90)	N		CL	0.28	0.14	0.12	67	
	00005-00001	6 X179(2)-6 X189(4)-6 X189(5)-13ARG90	AT/AT	3	0.048(2), 0.18(4), 0.18(5)	0.491,0.491	TS-D	Fill 1: ARG (90),Fill 2: ARG (90)	N		CL	0.28	0.16	0.25	67	
	00006-00001	5 X180(2)-5 X180(4)-5 CL-16/13ARG90	AT/AT	3	0.125(2), 0.125(4)	0.617,0.491	TS-D	Fill 1: ARG (90),Fill 2: ARG (90)	N		CL	0.28	0.20	0.24	67	
	00007-00001	6 X179(2)-6 X179(3)-24ARG90	AT/AT	2	0.048(2), 0.048(3)	0.947	TS-D	Fill 1: ARG (90)	N		CL	0.33	0.17	0.26	62	
	00008-00001	6 X179(2)-6 X189(3)-24ARG90	AT/AT	2	0.048(2), 0.18(3)	0.947	TS-D	Fill 1: ARG (90)	N		CL	0.34	0.18	0.28	62	
	00009-00001	5 X180(2)-5 X180(3)-26ARG90	AT/AT	2	0.125(2), 0.125(3)	1.026	TS-D	Fill 1: ARG (90)	N		CL	0.34	0.25	0.27	62	
	00010-00001	5 X180(2)-5 CL-26ARG90	AT/AT	2	0.125(2)	1.026	TS-D	Fill 1: ARG (90)	N		CL	0.35	0.27	0.30	60	

Baseline Information

Test Lab	Test Date	Test Size	Tested U-Value	Standard U-Value	Test Report Number
TFTL	03/14/2026	600mm x 1500mm	0.258	0.256	MED-6468d

Comments:

I hereby certify that all requirements for NFRC Certification Authorization have been met and that the above information is true and correct, to the best of my knowledge.

Authorized IA
Signature: _____