

NFRC Product Certification Authorization Report



Manufacturer: SourcePoint Doors and Windows LLC
Product Series: 70 Series Outswing Casement Window
Simulation Lab: SATI
Initial Cert. Date: 06/08/2026
Street: 4363 Northeast Expressway
Product Type: CSSV
Sim. Report #: S3844.01-116-45 R0
Re-Certification Date:
City/State/Zip: Atlanta, Georgia
Air Leakage:
Sim. Report Date: 05/07/2025
Revised Date: 01/01/1970
Print Date: 10/06/2026
Test Date: 11/12/2025
Expiration Date: 11/12/2030

CPD Number: SUU-M-2						IA: National Accreditation And Management Institute									
Status	Product Num.	Manufacturer Code	Frame/ Sash	Glaz Lyrs	Low-E (Surface)	Gap Width(s)	Spacer	Gap Fill	Grids	Dividers	Tint	U-Factor	SHGC	VT	Cond. Res
	00001-00001	Clear / Air / Clear / Air / Clear (5mm/5mm/5mm) 39mm IG	VR/VR	3		0.472,0.472	A1-D	Fill 1: AIR (100),Fill 2: AIR (100)	N		CL	0.33	0.37	0.40	54
	00001-00002	Clear / Air / Clear / Air / Clear (5mm/5mm/5mm) 39mm IG	VR/VR	3		0.472,0.472	A1-D	Fill 1: AIR (100),Fill 2: AIR (100)	S	0.75	CL	0.33	0.33	0.36	54
	00002-00001	Clear / Air / Clear / Air / Clear (5mm/5mm/5mm) 39mm IG	VR/VR	3		0.472,0.472	A1-D	Fill 1: AIR (100),Fill 2: AIR (100)	G	0.75	CL	0.33	0.33	0.36	54
	00002-00002	Clear / Air / Clear / Air / Clear (5mm/5mm/5mm) 39mm IG	VR/VR	3		0.472,0.472	A1-D	Fill 1: AIR (100),Fill 2: AIR (100)	S	0.75	CL	0.33	0.33	0.36	54
	00003-00001	OptiliteS116 / Air / Clear / Air / Clear (5mm/5mm/5mm) 39mm IG	VR/VR	3	0.076(2)	0.472,0.472	A1-D	Fill 1: AIR (100),Fill 2: AIR (100)	N		CL	0.29	0.29	0.39	59
	00003-00002	OptiliteS116 / Air / Clear / Air / Clear (5mm/5mm/5mm) 39mm IG	VR/VR	3	0.076(2)	0.472,0.472	A1-D	Fill 1: AIR (100),Fill 2: AIR (100)	S	0.75	CL	0.29	0.26	0.35	59
	00004-00001	OptiliteS116 / Air / Clear / Air / Clear (5mm/5mm/5mm) 39mm IG	VR/VR	3	0.076(2)	0.472,0.472	A1-D	Fill 1: AIR (100),Fill 2: AIR (100)	G	0.75	CL	0.30	0.26	0.35	59
	00004-00002	OptiliteS116 / Air / Clear / Air / Clear (5mm/5mm/5mm) 39mm IG	VR/VR	3	0.076(2)	0.472,0.472	A1-D	Fill 1: AIR (100),Fill 2: AIR (100)	S	0.75	CL	0.30	0.26	0.35	59
	00005-00001	OptiliteS116 / ARG90 / Clear / ARG90 / Clear (5mm/5mm/5mm) 39mm IG	VR/VR	3	0.076(2)	0.472,0.472	A1-D	Fill 1: ARG (90),Fill 2: ARG (90)	N		CL	0.27	0.29	0.39	60
	00005-00002	OptiliteS116 / ARG90 / Clear / ARG90 / Clear (5mm/5mm/5mm) 39mm IG	VR/VR	3	0.076(2)	0.472,0.472	A1-D	Fill 1: ARG (90),Fill 2: ARG (90)	S	0.75	CL	0.27	0.26	0.35	60
	00006-00001	OptiliteS116 / ARG90 / Clear / ARG90 / Clear (5mm/5mm/5mm) 39mm IG	VR/VR	3	0.076(2)	0.472,0.472	A1-D	Fill 1: ARG (90),Fill 2: ARG (90)	G	0.75	CL	0.29	0.26	0.35	60
	00006-00002	OptiliteS116 / ARG90 / Clear / ARG90 / Clear (5mm/5mm/5mm) 39mm IG	VR/VR	3	0.076(2)	0.472,0.472	A1-D	Fill 1: ARG (90),Fill 2: ARG (90)	S	0.75	CL	0.29	0.26	0.35	60
	00007-00001	OptiliteS116 / ARG90 / Clear / ARG90 / OptiliteS116 (5mm/5mm/5mm) 39mm IG	VR/VR	3	0.076(2), 0.076(5)	0.472,0.472	A1-D	Fill 1: ARG (90),Fill 2: ARG (90)	N		CL	0.24	0.27	0.38	64
	00007-00002	OptiliteS116 / ARG90 / Clear / ARG90 / OptiliteS116 (5mm/5mm/5mm) 39mm IG	VR/VR	3	0.076(2), 0.076(5)	0.472,0.472	A1-D	Fill 1: ARG (90),Fill 2: ARG (90)	S	0.75	CL	0.24	0.24	0.34	64
	00008-00001	OptiliteS116 / ARG90 / Clear / ARG90 / OptiliteS116 (5mm/5mm/5mm) 39mm IG	VR/VR	3	0.076(2), 0.076(5)	0.472,0.472	A1-D	Fill 1: ARG (90),Fill 2: ARG (90)	G	0.75	CL	0.26	0.24	0.34	64
	00008-00002	OptiliteS116 / ARG90 / Clear / ARG90 / OptiliteS116 (5mm/5mm/5mm) 39mm IG	VR/VR	3	0.076(2), 0.076(5)	0.472,0.472	A1-D	Fill 1: ARG (90),Fill 2: ARG (90)	S	0.75	CL	0.26	0.24	0.34	64

NFRC Product Certification Authorization Report



Manufacturer: SourcePoint Doors and Windows LLC
Street: 4363 Northeast Expressway
City/State/Zip: Atlanta, Georgia
Print Date: 10/06/2026

Product Series: 70 Series Outswing Casement Window
Product Type: CSSV
Air Leakage:

Simulation Lab: SATI
Sim. Report #: S3844.01-116-45 R0
Sim. Report Date: 05/07/2025
Test Date: 11/12/2025

Initial Cert. Date: 06/08/2026
Re-Certification Date:
Revised Date: 01/01/1970
Expiration Date: 11/12/2030

CPD Number: SUU-M-2						IA: National Accreditation And Management Institute									
Status	Product Num.	Manufacturer Code	Frame/ Sash	Glaz Lyrs	Low-E (Surface)	Gap Width(s)	Spacer	Gap Fill	Grids	Dividers	Tint	U-Factor	SHGC	VT	Cond. Res.
	00009-00001	Clear / Air / Clear / Air / Clear (6mm/6mm/6mm) 42mm IG	VR/VR	3		0.472,0.472	A1-D	Fill 1: AIR (100),Fill 2: AIR (100)	N		CL	0.33	0.38	0.40	54
	00009-00002	Clear / Air / Clear / Air / Clear (6mm/6mm/6mm) 42mm IG	VR/VR	3		0.472,0.472	A1-D	Fill 1: AIR (100),Fill 2: AIR (100)	S	0.75	CL	0.33	0.34	0.36	54
	00010-00001	Clear / Air / Clear / Air / Clear (6mm/6mm/6mm) 42mm IG	VR/VR	3		0.472,0.472	A1-D	Fill 1: AIR (100),Fill 2: AIR (100)	G	0.75	CL	0.33	0.34	0.36	54
	00010-00002	Clear / Air / Clear / Air / Clear (6mm/6mm/6mm) 42mm IG	VR/VR	3		0.472,0.472	A1-D	Fill 1: AIR (100),Fill 2: AIR (100)	S	0.75	CL	0.33	0.34	0.36	54
	00011-00001	OptisolarD80 / Air / Clear / Air / Clear (6mm/6mm/6mm) 42mm IG	VR/VR	3	0.072(2)	0.472,0.472	A1-D	Fill 1: AIR (100),Fill 2: AIR (100)	N		CL	0.29	0.20	0.35	59
	00011-00002	OptisolarD80 / Air / Clear / Air / Clear (6mm/6mm/6mm) 42mm IG	VR/VR	3	0.072(2)	0.472,0.472	A1-D	Fill 1: AIR (100),Fill 2: AIR (100)	S	0.75	CL	0.29	0.18	0.31	59
	00012-00001	OptisolarD80 / Air / Clear / Air / Clear (6mm/6mm/6mm) 42mm IG	VR/VR	3	0.072(2)	0.472,0.472	A1-D	Fill 1: AIR (100),Fill 2: AIR (100)	G	0.75	CL	0.30	0.18	0.31	59
	00012-00002	OptisolarD80 / Air / Clear / Air / Clear (6mm/6mm/6mm) 42mm IG	VR/VR	3	0.072(2)	0.472,0.472	A1-D	Fill 1: AIR (100),Fill 2: AIR (100)	S	0.75	CL	0.30	0.18	0.31	59
	00013-00001	OptisolarD80 / ARG90 / Clear / ARG90 / Clear (6mm/6mm/6mm) 42mm IG	VR/VR	3	0.072(2)	0.472,0.472	A1-D	Fill 1: ARG (90),Fill 2: ARG (90)	N		CL	0.27	0.20	0.35	61
	00013-00002	OptisolarD80 / ARG90 / Clear / ARG90 / Clear (6mm/6mm/6mm) 42mm IG	VR/VR	3	0.072(2)	0.472,0.472	A1-D	Fill 1: ARG (90),Fill 2: ARG (90)	S	0.75	CL	0.27	0.18	0.31	61
	00014-00001	OptisolarD80 / ARG90 / Clear / ARG90 / Clear (6mm/6mm/6mm) 42mm IG	VR/VR	3	0.072(2)	0.472,0.472	A1-D	Fill 1: ARG (90),Fill 2: ARG (90)	G	0.75	CL	0.29	0.18	0.31	61
	00014-00002	OptisolarD80 / ARG90 / Clear / ARG90 / Clear (6mm/6mm/6mm) 42mm IG	VR/VR	3	0.072(2)	0.472,0.472	A1-D	Fill 1: ARG (90),Fill 2: ARG (90)	S	0.75	CL	0.29	0.18	0.31	61
	00015-00001	OptisolarD80 / ARG90 / Clear / ARG90 / OptisolarD80 (6mm/6mm/6mm) 42mm IG	VR/VR	3	0.072(2), 0.072(5)	0.472,0.472	A1-D	Fill 1: ARG (90),Fill 2: ARG (90)	N		CL	0.24	0.18	0.30	64
	00015-00002	OptisolarD80 / ARG90 / Clear / ARG90 / OptisolarD80 (6mm/6mm/6mm) 42mm IG	VR/VR	3	0.072(2), 0.072(5)	0.472,0.472	A1-D	Fill 1: ARG (90),Fill 2: ARG (90)	S	0.75	CL	0.24	0.17	0.27	64
	00016-00001	OptisolarD80 / ARG90 / Clear / ARG90 / OptisolarD80 (6mm/6mm/6mm) 42mm IG	VR/VR	3	0.072(2), 0.072(5)	0.472,0.472	A1-D	Fill 1: ARG (90),Fill 2: ARG (90)	G	0.75	CL	0.27	0.17	0.27	64

NFRC Product Certification Authorization Report



Manufacturer: SourcePoint Doors and Windows LLC
Street: 4363 Northeast Expressway
City/State/Zip: Atlanta, Georgia
Print Date: 10/06/2026

Product Series: 70 Series Outswing Casement Window
Product Type: CSSV
Air Leakage:

Simulation Lab: SATI
Sim. Report #: S3844.01-116-45 R0
Sim. Report Date: 05/07/2025
Test Date: 11/12/2025

Initial Cert. Date: 06/08/2026
Re-Certification Date:
Revised Date: 01/01/1970
Expiration Date: 11/12/2030

CPD Number: SUU-M-2						IA: National Accreditation And Management Institute										
Status	Product Num.	Manufacturer Code	Frame/Sash	Glaz Lysr	Low-E (Surface)	Gap Width(s)	Spacer	Gap Fill	Grids	Dividers	Tint	U-Factor	SHGC	VT	Cond. Res.	
	00016-00002	OptisolarD80 / ARG90 / Clear / ARG90 / OptisolarD80 (6mm/6mm/6mm) 42mm IG	VR/VR	3	0.072(2), 0.072(5)	0.472,0.472	A1-D	Fill 1: ARG (90),Fill 2: ARG (90)	S	0.75	CL	0.27	0.17	0.27	64	
	00017-00001	Clear / Air / Clear (5mm/5mm) 26mm IG	VR/VR	2		0.630	A1-D	Fill 1: AIR (100)	N		CL	0.42	0.41	0.44	42	
	00017-00002	Clear / Air / Clear (5mm/5mm) 26mm IG	VR/VR	2		0.630	A1-D	Fill 1: AIR (100)	G	0.75	CL	0.42	0.37	0.39	42	
	00017-00003	Clear / Air / Clear (5mm/5mm) 26mm IG	VR/VR	2		0.630	A1-D	Fill 1: AIR (100)	S	0.75	CL	0.42	0.37	0.39	42	
	00018-00001	OptiliteS116 / Air / Clear (5mm/5mm) 26mm IG	VR/VR	2	0.076(2)	0.630	A1-D	Fill 1: AIR (100)	N		CL	0.34	0.32	0.43	51	
	00018-00002	OptiliteS116 / Air / Clear (5mm/5mm) 26mm IG	VR/VR	2	0.076(2)	0.630	A1-D	Fill 1: AIR (100)	G	0.75	CL	0.34	0.29	0.39	51	
	00018-00003	OptiliteS116 / Air / Clear (5mm/5mm) 26mm IG	VR/VR	2	0.076(2)	0.630	A1-D	Fill 1: AIR (100)	S	0.75	CL	0.34	0.29	0.39	51	
	00019-00001	OptiliteS116 / ARG90 / Clear (5mm/5mm) 26mm IG	VR/VR	2	0.076(2)	0.630	A1-D	Fill 1: ARG (90)	N		CL	0.32	0.32	0.43	53	
	00019-00002	OptiliteS116 / ARG90 / Clear (5mm/5mm) 26mm IG	VR/VR	2	0.076(2)	0.630	A1-D	Fill 1: ARG (90)	G	0.75	CL	0.32	0.29	0.39	53	
	00019-00003	OptiliteS116 / ARG90 / Clear (5mm/5mm) 26mm IG	VR/VR	2	0.076(2)	0.630	A1-D	Fill 1: ARG (90)	S	0.75	CL	0.32	0.29	0.39	53	
	00020-00001	Clear / Air / Clear (6mm/6mm) 26mm IG	VR/VR	2		0.551	A1-D	Fill 1: AIR (100)	N		CL	0.41	0.42	0.44	42	
	00020-00002	Clear / Air / Clear (6mm/6mm) 26mm IG	VR/VR	2		0.551	A1-D	Fill 1: AIR (100)	S	0.75	CL	0.41	0.38	0.39	42	
	00021-00001	Clear / Air / Clear (6mm/6mm) 26mm IG	VR/VR	2		0.551	A1-D	Fill 1: AIR (100)	G	0.75	CL	0.42	0.38	0.39	42	
	00021-00002	Clear / Air / Clear (6mm/6mm) 26mm IG	VR/VR	2		0.551	A1-D	Fill 1: AIR (100)	S	0.75	CL	0.42	0.38	0.39	42	
	00022-00001	OptisolarD80 / Air / Clear (6mm/6mm) 26mm IG	VR/VR	2	0.072(2)	0.551	A1-D	Fill 1: AIR (100)	N		CL	0.33	0.22	0.38	50	
	00022-00002	OptisolarD80 / Air / Clear (6mm/6mm) 26mm IG	VR/VR	2	0.072(2)	0.551	A1-D	Fill 1: AIR (100)	S	0.75	CL	0.33	0.20	0.34	50	
	00023-00001	OptisolarD80 / Air / Clear (6mm/6mm) 26mm IG	VR/VR	2	0.072(2)	0.551	A1-D	Fill 1: AIR (100)	G	0.75	CL	0.36	0.20	0.34	50	
	00023-00002	OptisolarD80 / Air / Clear (6mm/6mm) 26mm IG	VR/VR	2	0.072(2)	0.551	A1-D	Fill 1: AIR (100)	S	0.75	CL	0.36	0.20	0.34	50	

NFRC Product Certification Authorization Report



Manufacturer: SourcePoint Doors and Windows LLC
Street: 4363 Northeast Expressway
City/State/Zip: Atlanta, Georgia
Print Date: 10/06/2026

Product Series: 70 Series Outswing Casement Window
Product Type: CSSV
Air Leakage:

Simulation Lab: SATI
Sim. Report #: S3844.01-116-45 R0
Sim. Report Date: 05/07/2025
Test Date: 11/12/2025

Initial Cert. Date: 06/08/2026
Re-Certification Date:
Revised Date: 01/01/1970
Expiration Date: 11/12/2030

CPD Number: SUU-M-2						IA: National Accreditation And Management Institute									
Status	Product Num.	Manufacturer Code	Frame/ Sash	Glaz Lyrs	Low-E (Surface)	Gap Width(s)	Spacer	Gap Fill	Grids	Dividers	Tint	U-Factor	SHGC	VT	Cond. Res
	00024-00001	OptisolarD80 / ARG90 / Clear (6mm/6mm) 26mm IG	VR/VR	2	0.072(2)	0.551	A1-D	Fill 1: ARG (90)	N		CL	0.31	0.21	0.38	53
	00024-00002	OptisolarD80 / ARG90 / Clear (6mm/6mm) 26mm IG	VR/VR	2	0.072(2)	0.551	A1-D	Fill 1: ARG (90)	S	0.75	CL	0.31	0.19	0.34	53
	00025-00001	OptisolarD80 / ARG90 / Clear (6mm/6mm) 26mm IG	VR/VR	2	0.072(2)	0.551	A1-D	Fill 1: ARG (90)	G	0.75	CL	0.34	0.19	0.34	53
	00025-00002	OptisolarD80 / ARG90 / Clear (6mm/6mm) 26mm IG	VR/VR	2	0.072(2)	0.551	A1-D	Fill 1: ARG (90)	S	0.75	CL	0.34	0.19	0.34	53
	00026-00001	Clear / Air / Clear / Air / Clear (5mm/5mm/5mm) 39mm IG	VR/VR	3		0.472,0.472	TS-D	Fill 1: AIR (100),Fill 2: AIR (100)	N		CL	0.31	0.37	0.40	59
	00026-00002	Clear / Air / Clear / Air / Clear (5mm/5mm/5mm) 39mm IG	VR/VR	3		0.472,0.472	TS-D	Fill 1: AIR (100),Fill 2: AIR (100)	S	0.75	CL	0.31	0.33	0.36	59
	00027-00001	Clear / Air / Clear / Air / Clear (5mm/5mm/5mm) 39mm IG	VR/VR	3		0.472,0.472	TS-D	Fill 1: AIR (100),Fill 2: AIR (100)	G	0.75	CL	0.31	0.33	0.36	59
	00027-00002	Clear / Air / Clear / Air / Clear (5mm/5mm/5mm) 39mm IG	VR/VR	3		0.472,0.472	TS-D	Fill 1: AIR (100),Fill 2: AIR (100)	S	0.75	CL	0.31	0.33	0.36	59
	00028-00001	OptiliteS116 / Air / Clear / Air / Clear (5mm/5mm/5mm) 39mm IG	VR/VR	3	0.076(2)	0.472,0.472	TS-D	Fill 1: AIR (100),Fill 2: AIR (100)	N		CL	0.27	0.29	0.39	64
	00028-00002	OptiliteS116 / Air / Clear / Air / Clear (5mm/5mm/5mm) 39mm IG	VR/VR	3	0.076(2)	0.472,0.472	TS-D	Fill 1: AIR (100),Fill 2: AIR (100)	S	0.75	CL	0.27	0.26	0.35	64
	00029-00001	OptiliteS116 / Air / Clear / Air / Clear (5mm/5mm/5mm) 39mm IG	VR/VR	3	0.076(2)	0.472,0.472	TS-D	Fill 1: AIR (100),Fill 2: AIR (100)	G	0.75	CL	0.28	0.26	0.35	64
	00029-00002	OptiliteS116 / Air / Clear / Air / Clear (5mm/5mm/5mm) 39mm IG	VR/VR	3	0.076(2)	0.472,0.472	TS-D	Fill 1: AIR (100),Fill 2: AIR (100)	S	0.75	CL	0.28	0.26	0.35	64
	00030-00001	OptiliteS116 / ARG90 / Clear / ARG90 / Clear (5mm/5mm/5mm) 39mm IG	VR/VR	3	0.076(2)	0.472,0.472	TS-D	Fill 1: ARG (90),Fill 2: ARG (90)	N		CL	0.25	0.29	0.39	67
	00030-00002	OptiliteS116 / ARG90 / Clear / ARG90 / Clear (5mm/5mm/5mm) 39mm IG	VR/VR	3	0.076(2)	0.472,0.472	TS-D	Fill 1: ARG (90),Fill 2: ARG (90)	S	0.75	CL	0.25	0.26	0.35	67
	00031-00001	OptiliteS116 / ARG90 / Clear / ARG90 / Clear (5mm/5mm/5mm) 39mm IG	VR/VR	3	0.076(2)	0.472,0.472	TS-D	Fill 1: ARG (90),Fill 2: ARG (90)	G	0.75	CL	0.27	0.26	0.35	67
	00031-00002	OptiliteS116 / ARG90 / Clear / ARG90 / Clear (5mm/5mm/5mm) 39mm IG	VR/VR	3	0.076(2)	0.472,0.472	TS-D	Fill 1: ARG (90),Fill 2: ARG (90)	S	0.75	CL	0.27	0.26	0.35	67
	00032-00001	OptiliteS116 / ARG90 / Clear / ARG90 / OptiliteS116 (5mm/5mm/5mm) 39mm IG	VR/VR	3	0.076(2), 0.076(5)	0.472,0.472	TS-D	Fill 1: ARG (90),Fill 2: ARG (90)	N		CL	0.22	0.27	0.38	72

NFRC Product Certification Authorization Report



Manufacturer: SourcePoint Doors and Windows LLC
Street: 4363 Northeast Expressway
City/State/Zip: Atlanta, Georgia
Print Date: 10/06/2026

Product Series: 70 Series Outswing Casement Window
Product Type: CSSV
Air Leakage:

Simulation Lab: SATI
Sim. Report #: S3844.01-116-45 R0
Sim. Report Date: 05/07/2025
Test Date: 11/12/2025

Initial Cert. Date: 06/08/2026
Re-Certification Date:
Revised Date: 01/01/1970
Expiration Date: 11/12/2030

CPD Number: SUU-M-2						IA: National Accreditation And Management Institute										
Status	Product Num.	Manufacturer Code	Frame/ Sash	Glaz Lyrs	Low-E (Surface)	Gap Width(s)	Spacer	Gap Fill	Grids	Dividers	Tint	U-Factor	SHGC	VT	Cond. Res	
	00032-00002	OptiliteS116 / ARG90 / Clear / ARG90 / OptiliteS116 (5mm/5mm/5mm) 39mm IG	VR/VR	3	0.076(2), 0.076(5)	0.472,0.472	TS-D	Fill 1: ARG (90),Fill 2: ARG (90)	S	0.75	CL	0.22	0.24	0.34	72	
	00033-00001	OptiliteS116 / ARG90 / Clear / ARG90 / OptiliteS116 (5mm/5mm/5mm) 39mm IG	VR/VR	3	0.076(2), 0.076(5)	0.472,0.472	TS-D	Fill 1: ARG (90),Fill 2: ARG (90)	G	0.75	CL	0.24	0.24	0.34	72	
	00033-00002	OptiliteS116 / ARG90 / Clear / ARG90 / OptiliteS116 (5mm/5mm/5mm) 39mm IG	VR/VR	3	0.076(2), 0.076(5)	0.472,0.472	TS-D	Fill 1: ARG (90),Fill 2: ARG (90)	S	0.75	CL	0.24	0.24	0.34	72	
	00034-00001	Clear / Air / Clear / Air / Clear (6mm/6mm/6mm) 42mm IG	VR/VR	3		0.472,0.472	TS-D	Fill 1: AIR (100),Fill 2: AIR (100)	N		CL	0.31	0.38	0.40	59	
	00034-00002	Clear / Air / Clear / Air / Clear (6mm/6mm/6mm) 42mm IG	VR/VR	3		0.472,0.472	TS-D	Fill 1: AIR (100),Fill 2: AIR (100)	S	0.75	CL	0.31	0.34	0.36	59	
	00035-00001	Clear / Air / Clear / Air / Clear (6mm/6mm/6mm) 42mm IG	VR/VR	3		0.472,0.472	TS-D	Fill 1: AIR (100),Fill 2: AIR (100)	G	0.75	CL	0.31	0.34	0.36	59	
	00035-00002	Clear / Air / Clear / Air / Clear (6mm/6mm/6mm) 42mm IG	VR/VR	3		0.472,0.472	TS-D	Fill 1: AIR (100),Fill 2: AIR (100)	S	0.75	CL	0.31	0.34	0.36	59	
	00036-00001	OptisolarD80 / Air / Clear / Air / Clear (6mm/6mm/6mm) 42mm IG	VR/VR	3	0.072(2)	0.472,0.472	TS-D	Fill 1: AIR (100),Fill 2: AIR (100)	N		CL	0.27	0.20	0.35	65	
	00036-00002	OptisolarD80 / Air / Clear / Air / Clear (6mm/6mm/6mm) 42mm IG	VR/VR	3	0.072(2)	0.472,0.472	TS-D	Fill 1: AIR (100),Fill 2: AIR (100)	S	0.75	CL	0.27	0.18	0.31	65	
	00037-00001	OptisolarD80 / Air / Clear / Air / Clear (6mm/6mm/6mm) 42mm IG	VR/VR	3	0.072(2)	0.472,0.472	TS-D	Fill 1: AIR (100),Fill 2: AIR (100)	G	0.75	CL	0.28	0.18	0.31	65	
	00037-00002	OptisolarD80 / Air / Clear / Air / Clear (6mm/6mm/6mm) 42mm IG	VR/VR	3	0.072(2)	0.472,0.472	TS-D	Fill 1: AIR (100),Fill 2: AIR (100)	S	0.75	CL	0.28	0.18	0.31	65	
	00038-00001	OptisolarD80 / ARG90 / Clear / ARG90 / Clear (6mm/6mm/6mm) 42mm IG	VR/VR	3	0.072(2)	0.472,0.472	TS-D	Fill 1: ARG (90),Fill 2: ARG (90)	N		CL	0.25	0.20	0.35	67	
	00038-00002	OptisolarD80 / ARG90 / Clear / ARG90 / Clear (6mm/6mm/6mm) 42mm IG	VR/VR	3	0.072(2)	0.472,0.472	TS-D	Fill 1: ARG (90),Fill 2: ARG (90)	S	0.75	CL	0.25	0.18	0.31	67	
	00039-00001	OptisolarD80 / ARG90 / Clear / ARG90 / Clear (6mm/6mm/6mm) 42mm IG	VR/VR	3	0.072(2)	0.472,0.472	TS-D	Fill 1: ARG (90),Fill 2: ARG (90)	G	0.75	CL	0.27	0.18	0.31	67	
	00039-00002	OptisolarD80 / ARG90 / Clear / ARG90 / Clear (6mm/6mm/6mm) 42mm IG	VR/VR	3	0.072(2)	0.472,0.472	TS-D	Fill 1: ARG (90),Fill 2: ARG (90)	S	0.75	CL	0.27	0.18	0.31	67	
	00040-00001	OptisolarD80 / ARG90 / Clear / ARG90 / OptisolarD80 (6mm/6mm/6mm) 42mm IG	VR/VR	3	0.072(2), 0.072(5)	0.472,0.472	TS-D	Fill 1: ARG (90),Fill 2: ARG (90)	N		CL	0.22	0.18	0.30	71	

NFRC Product Certification Authorization Report



Manufacturer: SourcePoint Doors and Windows LLC
Street: 4363 Northeast Expressway
City/State/Zip: Atlanta, Georgia
Print Date: 10/06/2026

Product Series: 70 Series Outswing Casement Window
Product Type: CSSV
Air Leakage:

Simulation Lab: SATI
Sim. Report #: S3844.01-116-45 R0
Sim. Report Date: 05/07/2025
Test Date: 11/12/2025

Initial Cert. Date: 06/08/2026
Re-Certification Date:
Revised Date: 01/01/1970
Expiration Date: 11/12/2030

CPD Number: SUU-M-2						IA: National Accreditation And Management Institute										
Status	Product Num.	Manufacturer Code	Frame/Sash	Glaz Lys	Low-E (Surface)	Gap Width(s)	Spacer	Gap Fill	Grids	Dividers	Tint	U-Factor	SHGC	VT	Cond. Res.	
	00040-00002	OptisolarD80 / ARG90 / Clear / ARG90 / OptisolarD80 (6mm/6mm/6mm) 42mm IG	VR/VR	3	0.072(2), 0.072(5)	0.472,0.472	TS-D	Fill 1: ARG (90),Fill 2: ARG (90)	S	0.75	CL	0.22	0.17	0.27	71	
	00041-00001	OptisolarD80 / ARG90 / Clear / ARG90 / OptisolarD80 (6mm/6mm/6mm) 42mm IG	VR/VR	3	0.072(2), 0.072(5)	0.472,0.472	TS-D	Fill 1: ARG (90),Fill 2: ARG (90)	G	0.75	CL	0.24	0.17	0.27	71	
	00041-00002	OptisolarD80 / ARG90 / Clear / ARG90 / OptisolarD80 (6mm/6mm/6mm) 42mm IG	VR/VR	3	0.072(2), 0.072(5)	0.472,0.472	TS-D	Fill 1: ARG (90),Fill 2: ARG (90)	S	0.75	CL	0.24	0.17	0.27	71	
	00042-00001	Clear / Air / Clear (5mm/5mm) 26mm IG	VR/VR	2		0.630	TS-D	Fill 1: AIR (100)	N		CL	0.40	0.41	0.44	45	
	00042-00002	Clear / Air / Clear (5mm/5mm) 26mm IG	VR/VR	2		0.630	TS-D	Fill 1: AIR (100)	G	0.75	CL	0.40	0.37	0.39	45	
	00042-00003	Clear / Air / Clear (5mm/5mm) 26mm IG	VR/VR	2		0.630	TS-D	Fill 1: AIR (100)	S	0.75	CL	0.40	0.37	0.39	45	
	00043-00001	OptiliteS116 / Air / Clear (5mm/5mm) 26mm IG	VR/VR	2	0.076(2)	0.630	TS-D	Fill 1: AIR (100)	N		CL	0.32	0.32	0.43	55	
	00043-00002	OptiliteS116 / Air / Clear (5mm/5mm) 26mm IG	VR/VR	2	0.076(2)	0.630	TS-D	Fill 1: AIR (100)	G	0.75	CL	0.32	0.29	0.39	55	
	00043-00003	OptiliteS116 / Air / Clear (5mm/5mm) 26mm IG	VR/VR	2	0.076(2)	0.630	TS-D	Fill 1: AIR (100)	S	0.75	CL	0.32	0.29	0.39	55	
	00044-00001	OptiliteS116 / ARG90 / Clear (5mm/5mm) 26mm IG	VR/VR	2	0.076(2)	0.630	TS-D	Fill 1: ARG (90)	N		CL	0.30	0.32	0.43	59	
	00044-00002	OptiliteS116 / ARG90 / Clear (5mm/5mm) 26mm IG	VR/VR	2	0.076(2)	0.630	TS-D	Fill 1: ARG (90)	G	0.75	CL	0.30	0.29	0.39	59	
	00044-00003	OptiliteS116 / ARG90 / Clear (5mm/5mm) 26mm IG	VR/VR	2	0.076(2)	0.630	TS-D	Fill 1: ARG (90)	S	0.75	CL	0.30	0.29	0.39	59	
	00045-00001	Clear / Air / Clear (6mm/6mm) 26mm IG	VR/VR	2		0.551	TS-D	Fill 1: AIR (100)	N		CL	0.40	0.42	0.44	45	
	00045-00002	Clear / Air / Clear (6mm/6mm) 26mm IG	VR/VR	2		0.551	TS-D	Fill 1: AIR (100)	S	0.75	CL	0.40	0.38	0.39	45	
	00046-00001	Clear / Air / Clear (6mm/6mm) 26mm IG	VR/VR	2		0.551	TS-D	Fill 1: AIR (100)	G	0.75	CL	0.40	0.38	0.39	45	
	00046-00002	Clear / Air / Clear (6mm/6mm) 26mm IG	VR/VR	2		0.551	TS-D	Fill 1: AIR (100)	S	0.75	CL	0.40	0.38	0.39	45	
	00047-00001	OptisolarD80 / Air / Clear (6mm/6mm) 26mm IG	VR/VR	2	0.072(2)	0.551	TS-D	Fill 1: AIR (100)	N		CL	0.32	0.22	0.38	55	

NFRC Product Certification Authorization Report



Manufacturer: SourcePoint Doors and Windows LLC
Street: 4363 Northeast Expressway
City/State/Zip: Atlanta, Georgia
Print Date: 10/06/2026

Product Series: 70 Series Outswing Casement Window
Product Type: CSSV
Air Leakage:

Simulation Lab: SATI
Sim. Report #: S3844.01-116-45 R0
Sim. Report Date: 05/07/2025
Test Date: 11/12/2025

Initial Cert. Date: 06/08/2026
Re-Certification Date:
Revised Date: 01/01/1970
Expiration Date: 11/12/2030

CPD Number: SUU-M-2						IA: National Accreditation And Management Institute									
Status	Product Num.	Manufacturer Code	Frame/Sash	Glaz Lyrs	Low-E (Surface)	Gap Width(s)	Spacer	Gap Fill	Grids	Dividers	Tint	U-Factor	SHGC	VT	Cond. Res
	00047-00002	OptisolarD80 / Air / Clear (6mm/6mm) 26mm IG	VR/VR	2	0.072(2)	0.551	TS-D	Fill 1: AIR (100)	S	0.75	CL	0.32	0.20	0.34	55
	00048-00001	OptisolarD80 / Air / Clear (6mm/6mm) 26mm IG	VR/VR	2	0.072(2)	0.551	TS-D	Fill 1: AIR (100)	G	0.75	CL	0.34	0.20	0.34	55
	00048-00002	OptisolarD80 / Air / Clear (6mm/6mm) 26mm IG	VR/VR	2	0.072(2)	0.551	TS-D	Fill 1: AIR (100)	S	0.75	CL	0.34	0.20	0.34	55
	00049-00001	OptisolarD80 / ARG90 / Clear (6mm/6mm) 26mm IG	VR/VR	2	0.072(2)	0.551	TS-D	Fill 1: ARG (90)	N		CL	0.30	0.21	0.38	58
	00049-00002	OptisolarD80 / ARG90 / Clear (6mm/6mm) 26mm IG	VR/VR	2	0.072(2)	0.551	TS-D	Fill 1: ARG (90)	S	0.75	CL	0.30	0.19	0.34	58
	00050-00001	OptisolarD80 / ARG90 / Clear (6mm/6mm) 26mm IG	VR/VR	2	0.072(2)	0.551	TS-D	Fill 1: ARG (90)	G	0.75	CL	0.33	0.19	0.34	58
	00050-00002	OptisolarD80 / ARG90 / Clear (6mm/6mm) 26mm IG	VR/VR	2	0.072(2)	0.551	TS-D	Fill 1: ARG (90)	S	0.75	CL	0.33	0.19	0.34	58

Baseline Information

Test Lab	Test Date	Test Size	Tested U-Value	Standard U-Value	Test Report Number
TATI	11/12/2025	600mm x 1499mm	0.247	0.244	S3845.01-116-46

Comments:

I hereby certify that all requirements for NFRC Certification Authorization have been met and that the above information is true and correct, to the best of my knowledge.

Authorized IA
Signature: _____