

NFRC Product Certification Authorization Report



Manufacturer: SourcePoint Doors and Windows LLC
Street: 4363 Northeast Expressway
City/State/Zip: Atlanta, Georgia
Product Series: 82 Series Fixed Window
Product Type: FIXD
Air Leakage:
Simulation Lab: SATI
Sim. Report #: S3851.01-116-45 R0
Sim. Report Date: 05/15/2025
Initial Cert. Date: 06/08/2026
Re-Certification Date:
Revised Date: 01/01/1970
Print Date: 10/06/2026
Test Date: 03/07/2026
Expiration Date: 03/07/2031

CPD Number: SUU-M-4						IA: National Accreditation And Management Institute										
Status	Product Num.	Manufacturer Code	Frame/ Sash	Glaz Lyrs	Low-E (Surface)	Gap Width(s)	Spacer	Gap Fill	Grids	Dividers	Tint	U-Factor	SHGC	VT	Cond. Res	
	00001-00001	S116 / Air / Clear (3mm/3mm) 22mm IG	VY/NA	2	0.057(2)	0.630	A1-D	Fill 1: AIR (100)	N		CL	0.33	0.48	0.65	51	
	00001-00002	S116 / Air / Clear (3mm/3mm) 22mm IG	VY/NA	2	0.057(2)	0.630	A1-D	Fill 1: AIR (100)	S	0.75	CL	0.33	0.43	0.58	51	
	00002-00001	S116 / Air / Clear (3mm/3mm) 22mm IG	VY/NA	2	0.057(2)	0.630	A1-D	Fill 1: AIR (100)	G	0.75	CL	0.35	0.43	0.58	51	
	00002-00002	S116 / Air / Clear (3mm/3mm) 22mm IG	VY/NA	2	0.057(2)	0.630	A1-D	Fill 1: AIR (100)	S	0.75	CL	0.35	0.43	0.58	51	
	00003-00001	S116 / ARG90 / Clear (3mm/3mm) 22mm IG	VY/NA	2	0.057(2)	0.630	A1-D	Fill 1: ARG (90)	N		CL	0.30	0.48	0.65	53	
	00003-00002	S116 / ARG90 / Clear (3mm/3mm) 22mm IG	VY/NA	2	0.057(2)	0.630	A1-D	Fill 1: ARG (90)	S	0.75	CL	0.30	0.43	0.58	53	
	00004-00001	S116 / ARG90 / Clear (3mm/3mm) 22mm IG	VY/NA	2	0.057(2)	0.630	A1-D	Fill 1: ARG (90)	G	0.75	CL	0.31	0.43	0.58	53	
	00004-00002	S116 / ARG90 / Clear (3mm/3mm) 22mm IG	VY/NA	2	0.057(2)	0.630	A1-D	Fill 1: ARG (90)	S	0.75	CL	0.31	0.43	0.58	53	
	00005-00001	S116 / Air / Clear (5mm/5mm) 22mm IG	VY/NA	2	0.076(2)	0.472	A1-D	Fill 1: AIR (100)	N		CL	0.33	0.46	0.64	48	
	00005-00002	S116 / Air / Clear (5mm/5mm) 22mm IG	VY/NA	2	0.076(2)	0.472	A1-D	Fill 1: AIR (100)	S	0.75	CL	0.33	0.41	0.57	48	
	00006-00001	S116 / Air / Clear (5mm/5mm) 22mm IG	VY/NA	2	0.076(2)	0.472	A1-D	Fill 1: AIR (100)	G	0.75	CL	0.39	0.41	0.57	48	
	00006-00002	S116 / Air / Clear (5mm/5mm) 22mm IG	VY/NA	2	0.076(2)	0.472	A1-D	Fill 1: AIR (100)	S	0.75	CL	0.39	0.41	0.57	48	
	00007-00001	S116 / ARG90 / Clear (5mm/5mm) 22mm IG	VY/NA	2	0.076(2)	0.472	A1-D	Fill 1: ARG (90)	N		CL	0.30	0.46	0.64	51	
	00007-00002	S116 / ARG90 / Clear (5mm/5mm) 22mm IG	VY/NA	2	0.076(2)	0.472	A1-D	Fill 1: ARG (90)	S	0.75	CL	0.30	0.41	0.57	51	
	00008-00001	S116 / ARG90 / Clear (5mm/5mm) 22mm IG	VY/NA	2	0.076(2)	0.472	A1-D	Fill 1: ARG (90)	G	0.75	CL	0.35	0.41	0.57	51	
	00008-00002	S116 / ARG90 / Clear (5mm/5mm) 22mm IG	VY/NA	2	0.076(2)	0.472	A1-D	Fill 1: ARG (90)	S	0.75	CL	0.35	0.41	0.57	51	
	00009-00001	Clear / Air / Clear (3mm/3mm) 22mm IG	VY/NA	2		0.630	A1-D	Fill 1: AIR (100)	N		CL	0.46	0.64	0.67	41	
	00009-00002	Clear / Air / Clear (3mm/3mm) 22mm IG	VY/NA	2		0.630	A1-D	Fill 1: AIR (100)	S	0.75	CL	0.46	0.57	0.60	41	
	00010-00001	Clear / Air / Clear (3mm/3mm) 22mm IG	VY/NA	2		0.630	A1-D	Fill 1: AIR (100)	G	0.75	CL	0.47	0.57	0.60	41	
	00010-00002	Clear / Air / Clear (3mm/3mm) 22mm IG	VY/NA	2		0.630	A1-D	Fill 1: AIR (100)	S	0.75	CL	0.47	0.57	0.60	41	

NFRC Product Certification Authorization Report



Manufacturer: SourcePoint Doors and Windows LLC
Street: 4363 Northeast Expressway
City/State/Zip: Atlanta, Georgia
Print Date: 10/06/2026

Product Series: 82 Series Fixed Window
Product Type: FIXD
Air Leakage:

Simulation Lab: SATI
Sim. Report #: S3851.01-116-45 R0
Sim. Report Date: 05/15/2025
Test Date: 03/07/2026

Initial Cert. Date: 06/08/2026
Re-Certification Date:
Revised Date: 01/01/1970
Expiration Date: 03/07/2031

CPD Number: SUU-M-4						IA: National Accreditation And Management Institute										
Status	Product Num.	Manufacturer Code	Frame/ Sash	Glaz Lyrs	Low-E (Surface)	Gap Width(s)	Spacer	Gap Fill	Grids	Dividers	Tint	U-Factor	SHGC	VT	Cond. Res.	
	00011-00001	Clear / Air / Clear (5mm/5mm) 22mm IG	VY/NA	2		0.472	A1-D	Fill 1: AIR (100)	N		CL	0.46	0.60	0.65	40	
	00011-00002	Clear / Air / Clear (5mm/5mm) 22mm IG	VY/NA	2		0.472	A1-D	Fill 1: AIR (100)	S	0.75	CL	0.46	0.54	0.58	40	
	00012-00001	Clear / Air / Clear (5mm/5mm) 22mm IG	VY/NA	2		0.472	A1-D	Fill 1: AIR (100)	G	0.75	CL	0.50	0.54	0.58	40	
	00012-00002	Clear / Air / Clear (5mm/5mm) 22mm IG	VY/NA	2		0.472	A1-D	Fill 1: AIR (100)	S	0.75	CL	0.50	0.54	0.58	40	
	00013-00001	S116 / ARG90 / S116 (3mm/3mm) 22mm IG	VY/NA	2	0.057(2), 0.057(3)	0.630	A1-D	Fill 1: ARG (90)	N		CL	0.29	0.44	0.64	54	
	00013-00002	S116 / ARG90 / S116 (3mm/3mm) 22mm IG	VY/NA	2	0.057(2), 0.057(3)	0.630	A1-D	Fill 1: ARG (90)	S	0.75	CL	0.29	0.40	0.57	54	
	00014-00001	S116 / ARG90 / S116 (3mm/3mm) 22mm IG	VY/NA	2	0.057(2), 0.057(3)	0.630	A1-D	Fill 1: ARG (90)	G	0.75	CL	0.30	0.40	0.57	54	
	00014-00002	S116 / ARG90 / S116 (3mm/3mm) 22mm IG	VY/NA	2	0.057(2), 0.057(3)	0.630	A1-D	Fill 1: ARG (90)	S	0.75	CL	0.30	0.40	0.57	54	
	00015-00001	S116 / ARG90 / S116 (5mm/5mm) 22mm IG	VY/NA	2	0.076(2), 0.076(3)	0.472	A1-D	Fill 1: ARG (90)	N		CL	0.29	0.43	0.63	52	
	00015-00002	S116 / ARG90 / S116 (5mm/5mm) 22mm IG	VY/NA	2	0.076(2), 0.076(3)	0.472	A1-D	Fill 1: ARG (90)	S	0.75	CL	0.29	0.39	0.56	52	
	00016-00001	S116 / ARG90 / S116 (5mm/5mm) 22mm IG	VY/NA	2	0.076(2), 0.076(3)	0.472	A1-D	Fill 1: ARG (90)	G	0.75	CL	0.34	0.39	0.56	52	
	00016-00002	S116 / ARG90 / S116 (5mm/5mm) 22mm IG	VY/NA	2	0.076(2), 0.076(3)	0.472	A1-D	Fill 1: ARG (90)	S	0.75	CL	0.34	0.39	0.56	52	
	00017-00001	S116 / Air / Clear (3mm/3mm) 18mm IG	VY/NA	2	0.057(2)	0.472	A1-D	Fill 1: AIR (100)	N		CL	0.32	0.48	0.65	50	
	00017-00002	S116 / Air / Clear (3mm/3mm) 18mm IG	VY/NA	2	0.057(2)	0.472	A1-D	Fill 1: AIR (100)	S	0.75	CL	0.32	0.43	0.58	50	
	00018-00001	S116 / Air / Clear (3mm/3mm) 18mm IG	VY/NA	2	0.057(2)	0.472	A1-D	Fill 1: AIR (100)	G	0.75	CL	0.38	0.43	0.58	50	
	00018-00002	S116 / Air / Clear (3mm/3mm) 18mm IG	VY/NA	2	0.057(2)	0.472	A1-D	Fill 1: AIR (100)	S	0.75	CL	0.38	0.43	0.58	50	
	00019-00001	S116 / ARG90 / Clear (3mm/3mm) 18mm IG	VY/NA	2	0.057(2)	0.472	A1-D	Fill 1: ARG (90)	N		CL	0.29	0.48	0.65	52	
	00019-00002	S116 / ARG90 / Clear (3mm/3mm) 18mm IG	VY/NA	2	0.057(2)	0.472	A1-D	Fill 1: ARG (90)	S	0.75	CL	0.29	0.43	0.58	52	
	00020-00001	S116 / ARG90 / Clear (3mm/3mm) 18mm IG	VY/NA	2	0.057(2)	0.472	A1-D	Fill 1: ARG (90)	G	0.75	CL	0.34	0.43	0.58	52	

NFRC Product Certification Authorization Report



Manufacturer: SourcePoint Doors and Windows LLC
Street: 4363 Northeast Expressway
City/State/Zip: Atlanta, Georgia
Print Date: 10/06/2026

Product Series: 82 Series Fixed Window
Product Type: FIXD
Air Leakage:

Simulation Lab: SATI
Sim. Report #: S3851.01-116-45 R0
Sim. Report Date: 05/15/2025
Test Date: 03/07/2026

Initial Cert. Date: 06/08/2026
Re-Certification Date:
Revised Date: 01/01/1970
Expiration Date: 03/07/2031

CPD Number: SUU-M-4						IA: National Accreditation And Management Institute									
Status	Product Num.	Manufacturer Code	Frame/ Sash	Glaz Lyrs	Low-E (Surface)	Gap Width(s)	Spacer	Gap Fill	Grids	Dividers	Tint	U-Factor	SHGC	VT	Cond. Res
	00020-00002	S116 / ARG90 / Clear (3mm/3mm) 18mm IG	VY/NA	2	0.057(2)	0.472	A1-D	Fill 1: ARG (90)	S	0.75	CL	0.34	0.43	0.58	52
	00021-00001	S116 / Air / Clear (5mm/5mm) 19mm IG	VY/NA	2	0.076(2)	0.354	A1-D	Fill 1: AIR (100)	N		CL	0.36	0.46	0.64	46
	00021-00002	S116 / Air / Clear (5mm/5mm) 19mm IG	VY/NA	2	0.076(2)	0.354	A1-D	Fill 1: AIR (100)	S	0.75	CL	0.36	0.42	0.57	46
	00022-00001	S116 / Air / Clear (5mm/5mm) 19mm IG	VY/NA	2	0.076(2)	0.354	A1-D	Fill 1: AIR (100)	G	0.75	CL	0.39	0.42	0.57	46
	00022-00002	S116 / Air / Clear (5mm/5mm) 19mm IG	VY/NA	2	0.076(2)	0.354	A1-D	Fill 1: AIR (100)	S	0.75	CL	0.39	0.42	0.57	46
	00023-00001	S116 / ARG90 / Clear (5mm/5mm) 19mm IG	VY/NA	2	0.076(2)	0.354	A1-D	Fill 1: ARG (90)	N		CL	0.31	0.46	0.64	49
	00023-00002	S116 / ARG90 / Clear (5mm/5mm) 19mm IG	VY/NA	2	0.076(2)	0.354	A1-D	Fill 1: ARG (90)	S	0.75	CL	0.31	0.41	0.57	49
	00024-00001	S116 / ARG90 / Clear (5mm/5mm) 19mm IG	VY/NA	2	0.076(2)	0.354	A1-D	Fill 1: ARG (90)	G	0.75	CL	0.35	0.41	0.57	49
	00024-00002	S116 / ARG90 / Clear (5mm/5mm) 19mm IG	VY/NA	2	0.076(2)	0.354	A1-D	Fill 1: ARG (90)	S	0.75	CL	0.35	0.41	0.57	49
	00025-00001	Clear / Air / Clear (3mm/3mm) 18mm IG	VY/NA	2		0.472	A1-D	Fill 1: AIR (100)	N		CL	0.46	0.64	0.67	41
	00025-00002	Clear / Air / Clear (3mm/3mm) 18mm IG	VY/NA	2		0.472	A1-D	Fill 1: AIR (100)	S	0.75	CL	0.46	0.57	0.60	41
	00026-00001	Clear / Air / Clear (3mm/3mm) 18mm IG	VY/NA	2		0.472	A1-D	Fill 1: AIR (100)	G	0.75	CL	0.50	0.57	0.60	41
	00026-00002	Clear / Air / Clear (3mm/3mm) 18mm IG	VY/NA	2		0.472	A1-D	Fill 1: AIR (100)	S	0.75	CL	0.50	0.57	0.60	41
	00027-00001	Clear / Air / Clear (5mm/5mm) 19mm IG	VY/NA	2		0.354	A1-D	Fill 1: AIR (100)	N		CL	0.48	0.60	0.65	39
	00027-00002	Clear / Air / Clear (5mm/5mm) 19mm IG	VY/NA	2		0.354	A1-D	Fill 1: AIR (100)	S	0.75	CL	0.48	0.54	0.58	39
	00028-00001	Clear / Air / Clear (5mm/5mm) 19mm IG	VY/NA	2		0.354	A1-D	Fill 1: AIR (100)	G	0.75	CL	0.50	0.54	0.58	39
	00028-00002	Clear / Air / Clear (5mm/5mm) 19mm IG	VY/NA	2		0.354	A1-D	Fill 1: AIR (100)	S	0.75	CL	0.50	0.54	0.58	39
	00029-00001	S116 / ARG90 / S116 (3mm/3mm) 18mm IG	VY/NA	2	0.057(2), 0.057(3)	0.472	A1-D	Fill 1: ARG (90)	N		CL	0.28	0.44	0.64	53
	00029-00002	S116 / ARG90 / S116 (3mm/3mm) 18mm IG	VY/NA	2	0.057(2), 0.057(3)	0.472	A1-D	Fill 1: ARG (90)	S	0.75	CL	0.28	0.40	0.57	53
	00030-00001	S116 / ARG90 / S116 (3mm/3mm) 18mm IG	VY/NA	2	0.057(2), 0.057(3)	0.472	A1-D	Fill 1: ARG (90)	G	0.75	CL	0.33	0.40	0.57	53

NFRC Product Certification Authorization Report



Manufacturer: SourcePoint Doors and Windows LLC
Street: 4363 Northeast Expressway
City/State/Zip: Atlanta, Georgia
Product Series: 82 Series Fixed Window
Product Type: FIXD
Air Leakage:
Simulation Lab: SATI
Sim. Report #: S3851.01-116-45 R0
Sim. Report Date: 05/15/2025
Initial Cert. Date: 06/08/2026
Re-Certification Date:
Revised Date: 01/01/1970
Print Date: 10/06/2026
Test Date: 03/07/2026
Expiration Date: 03/07/2031

CPD Number: SUU-M-4						IA: National Accreditation And Management Institute										
Status	Product Num.	Manufacturer Code	Frame/ Sash	Glaz Lyrs	Low-E (Surface)	Gap Width(s)	Spacer	Gap Fill	Grids	Dividers	Tint	U-Factor	SHGC	VT	Cond. Res	
	00030-00002	S116 / ARG90 / S116 (3mm/3mm) 18mm IG	VY/NA	2	0.057(2), 0.057(3)	0.472	A1-D	Fill 1: ARG (90)	S	0.75	CL	0.33	0.40	0.57	53	
	00031-00001	S116 / ARG90 / S116 (5mm/5mm) 19mm IG	VY/NA	2	0.076(2), 0.076(3)	0.354	A1-D	Fill 1: ARG (90)	N		CL	0.30	0.43	0.63	50	
	00031-00002	S116 / ARG90 / S116 (5mm/5mm) 19mm IG	VY/NA	2	0.076(2), 0.076(3)	0.354	A1-D	Fill 1: ARG (90)	S	0.75	CL	0.30	0.39	0.56	50	
	00032-00001	S116 / ARG90 / S116 (5mm/5mm) 19mm IG	VY/NA	2	0.076(2), 0.076(3)	0.354	A1-D	Fill 1: ARG (90)	G	0.75	CL	0.33	0.39	0.56	50	
	00032-00002	S116 / ARG90 / S116 (5mm/5mm) 19mm IG	VY/NA	2	0.076(2), 0.076(3)	0.354	A1-D	Fill 1: ARG (90)	S	0.75	CL	0.33	0.39	0.56	50	
	00033-00001	S116 / Air / Clear (3mm/3mm) 22mm IG	VY/NA	2	0.057(2)	0.630	TS-D	Fill 1: AIR (100)	N		CL	0.32	0.48	0.65	56	
	00033-00002	S116 / Air / Clear (3mm/3mm) 22mm IG	VY/NA	2	0.057(2)	0.630	TS-D	Fill 1: AIR (100)	S	0.75	CL	0.32	0.43	0.58	56	
	00034-00001	S116 / Air / Clear (3mm/3mm) 22mm IG	VY/NA	2	0.057(2)	0.630	TS-D	Fill 1: AIR (100)	G	0.75	CL	0.34	0.43	0.58	56	
	00034-00002	S116 / Air / Clear (3mm/3mm) 22mm IG	VY/NA	2	0.057(2)	0.630	TS-D	Fill 1: AIR (100)	S	0.75	CL	0.34	0.43	0.58	56	
	00035-00001	S116 / ARG90 / Clear (3mm/3mm) 22mm IG	VY/NA	2	0.057(2)	0.630	TS-D	Fill 1: ARG (90)	N		CL	0.28	0.48	0.65	60	
	00035-00002	S116 / ARG90 / Clear (3mm/3mm) 22mm IG	VY/NA	2	0.057(2)	0.630	TS-D	Fill 1: ARG (90)	S	0.75	CL	0.28	0.43	0.58	60	
	00036-00001	S116 / ARG90 / Clear (3mm/3mm) 22mm IG	VY/NA	2	0.057(2)	0.630	TS-D	Fill 1: ARG (90)	G	0.75	CL	0.30	0.43	0.58	60	
	00036-00002	S116 / ARG90 / Clear (3mm/3mm) 22mm IG	VY/NA	2	0.057(2)	0.630	TS-D	Fill 1: ARG (90)	S	0.75	CL	0.30	0.43	0.58	60	
	00037-00001	S116 / Air / Clear (5mm/5mm) 22mm IG	VY/NA	2	0.076(2)	0.472	TS-D	Fill 1: AIR (100)	N		CL	0.32	0.46	0.64	54	
	00037-00002	S116 / Air / Clear (5mm/5mm) 22mm IG	VY/NA	2	0.076(2)	0.472	TS-D	Fill 1: AIR (100)	S	0.75	CL	0.32	0.41	0.57	54	
	00038-00001	S116 / Air / Clear (5mm/5mm) 22mm IG	VY/NA	2	0.076(2)	0.472	TS-D	Fill 1: AIR (100)	G	0.75	CL	0.37	0.41	0.57	53	
	00038-00002	S116 / Air / Clear (5mm/5mm) 22mm IG	VY/NA	2	0.076(2)	0.472	TS-D	Fill 1: AIR (100)	S	0.75	CL	0.37	0.41	0.57	53	
	00039-00001	S116 / ARG90 / Clear (5mm/5mm) 22mm IG	VY/NA	2	0.076(2)	0.472	TS-D	Fill 1: ARG (90)	N		CL	0.28	0.46	0.64	57	
	00039-00002	S116 / ARG90 / Clear (5mm/5mm) 22mm IG	VY/NA	2	0.076(2)	0.472	TS-D	Fill 1: ARG (90)	S	0.75	CL	0.28	0.41	0.57	57	

NFRC Product Certification Authorization Report



Manufacturer: SourcePoint Doors and Windows LLC
Street: 4363 Northeast Expressway
City/State/Zip: Atlanta, Georgia
Product Series: 82 Series Fixed Window
Product Type: FIXD
Air Leakage:
Simulation Lab: SATI
Sim. Report #: S3851.01-116-45 R0
Sim. Report Date: 05/15/2025
Initial Cert. Date: 06/08/2026
Re-Certification Date:
Revised Date: 01/01/1970
Print Date: 10/06/2026
Test Date: 03/07/2026
Expiration Date: 03/07/2031

CPD Number: SUU-M-4						IA: National Accreditation And Management Institute									
Status	Product Num.	Manufacturer Code	Frame/ Sash	Glaz Lyrs	Low-E (Surface)	Gap Width(s)	Spacer	Gap Fill	Grids	Dividers	Tint	U-Factor	SHGC	VT	Cond. Res
	00040-00001	S116 / ARG90 / Clear (5mm/5mm) 22mm IG	VY/NA	2	0.076(2)	0.472	TS-D	Fill 1: ARG (90)	G	0.75	CL	0.33	0.41	0.57	57
	00040-00002	S116 / ARG90 / Clear (5mm/5mm) 22mm IG	VY/NA	2	0.076(2)	0.472	TS-D	Fill 1: ARG (90)	S	0.75	CL	0.33	0.41	0.57	57
	00041-00001	Clear / Air / Clear (3mm/3mm) 22mm IG	VY/NA	2		0.630	TS-D	Fill 1: AIR (100)	N		CL	0.45	0.64	0.67	45
	00041-00002	Clear / Air / Clear (3mm/3mm) 22mm IG	VY/NA	2		0.630	TS-D	Fill 1: AIR (100)	S	0.75	CL	0.45	0.57	0.60	45
	00042-00001	Clear / Air / Clear (3mm/3mm) 22mm IG	VY/NA	2		0.630	TS-D	Fill 1: AIR (100)	G	0.75	CL	0.46	0.57	0.60	45
	00042-00002	Clear / Air / Clear (3mm/3mm) 22mm IG	VY/NA	2		0.630	TS-D	Fill 1: AIR (100)	S	0.75	CL	0.46	0.57	0.60	45
	00043-00001	Clear / Air / Clear (5mm/5mm) 22mm IG	VY/NA	2		0.472	TS-D	Fill 1: AIR (100)	N		CL	0.45	0.60	0.65	44
	00043-00002	Clear / Air / Clear (5mm/5mm) 22mm IG	VY/NA	2		0.472	TS-D	Fill 1: AIR (100)	S	0.75	CL	0.45	0.54	0.58	44
	00044-00001	Clear / Air / Clear (5mm/5mm) 22mm IG	VY/NA	2		0.472	TS-D	Fill 1: AIR (100)	G	0.75	CL	0.49	0.54	0.58	42
	00044-00002	Clear / Air / Clear (5mm/5mm) 22mm IG	VY/NA	2		0.472	TS-D	Fill 1: AIR (100)	S	0.75	CL	0.49	0.54	0.58	42
	00045-00001	S116 / ARG90 / S116 (3mm/3mm) 22mm IG	VY/NA	2	0.057(2), 0.057(3)	0.630	TS-D	Fill 1: ARG (90)	N		CL	0.27	0.44	0.64	61
	00045-00002	S116 / ARG90 / S116 (3mm/3mm) 22mm IG	VY/NA	2	0.057(2), 0.057(3)	0.630	TS-D	Fill 1: ARG (90)	S	0.75	CL	0.27	0.40	0.57	61
	00046-00001	S116 / ARG90 / S116 (3mm/3mm) 22mm IG	VY/NA	2	0.057(2), 0.057(3)	0.630	TS-D	Fill 1: ARG (90)	G	0.75	CL	0.29	0.40	0.57	61
	00046-00002	S116 / ARG90 / S116 (3mm/3mm) 22mm IG	VY/NA	2	0.057(2), 0.057(3)	0.630	TS-D	Fill 1: ARG (90)	S	0.75	CL	0.29	0.40	0.57	61
	00047-00001	S116 / ARG90 / S116 (5mm/5mm) 22mm IG	VY/NA	2	0.076(2), 0.076(3)	0.472	TS-D	Fill 1: ARG (90)	N		CL	0.27	0.43	0.63	58
	00047-00002	S116 / ARG90 / S116 (5mm/5mm) 22mm IG	VY/NA	2	0.076(2), 0.076(3)	0.472	TS-D	Fill 1: ARG (90)	S	0.75	CL	0.27	0.39	0.56	58
	00048-00001	S116 / ARG90 / S116 (5mm/5mm) 22mm IG	VY/NA	2	0.076(2), 0.076(3)	0.472	TS-D	Fill 1: ARG (90)	G	0.75	CL	0.32	0.39	0.56	58
	00048-00002	S116 / ARG90 / S116 (5mm/5mm) 22mm IG	VY/NA	2	0.076(2), 0.076(3)	0.472	TS-D	Fill 1: ARG (90)	S	0.75	CL	0.32	0.39	0.56	58
	00049-00001	S116 / Air / Clear (3mm/3mm) 18mm IG	VY/NA	2	0.057(2)	0.472	TS-D	Fill 1: AIR (100)	N		CL	0.31	0.48	0.65	54
	00049-00002	S116 / Air / Clear (3mm/3mm) 18mm IG	VY/NA	2	0.057(2)	0.472	TS-D	Fill 1: AIR (100)	S	0.75	CL	0.31	0.43	0.58	54

NFRC Product Certification Authorization Report



Manufacturer: SourcePoint Doors and Windows LLC
Street: 4363 Northeast Expressway
City/State/Zip: Atlanta, Georgia
Print Date: 10/06/2026

Product Series: 82 Series Fixed Window
Product Type: FIXD
Air Leakage:

Simulation Lab: SATI
Sim. Report #: S3851.01-116-45 R0
Sim. Report Date: 05/15/2025
Test Date: 03/07/2026

Initial Cert. Date: 06/08/2026
Re-Certification Date:
Revised Date: 01/01/1970
Expiration Date: 03/07/2031

CPD Number: SUU-M-4						IA: National Accreditation And Management Institute										
Status	Product Num.	Manufacturer Code	Frame/ Sash	Glaz Lyrs	Low-E (Surface)	Gap Width(s)	Spacer	Gap Fill	Grids	Dividers	Tint	U-Factor	SHGC	VT	Cond. Res	
	00050-00001	S116 / Air / Clear (3mm/3mm) 18mm IG	VY/NA	2	0.057(2)	0.472	TS-D	Fill 1: AIR (100)	G	0.75	CL	0.37	0.43	0.58	52	
	00050-00002	S116 / Air / Clear (3mm/3mm) 18mm IG	VY/NA	2	0.057(2)	0.472	TS-D	Fill 1: AIR (100)	S	0.75	CL	0.37	0.43	0.58	52	
	00051-00001	S116 / ARG90 / Clear (3mm/3mm) 18mm IG	VY/NA	2	0.057(2)	0.472	TS-D	Fill 1: ARG (90)	N		CL	0.28	0.48	0.65	58	
	00051-00002	S116 / ARG90 / Clear (3mm/3mm) 18mm IG	VY/NA	2	0.057(2)	0.472	TS-D	Fill 1: ARG (90)	S	0.75	CL	0.28	0.43	0.58	58	
	00052-00001	S116 / ARG90 / Clear (3mm/3mm) 18mm IG	VY/NA	2	0.057(2)	0.472	TS-D	Fill 1: ARG (90)	G	0.75	CL	0.33	0.43	0.58	57	
	00052-00002	S116 / ARG90 / Clear (3mm/3mm) 18mm IG	VY/NA	2	0.057(2)	0.472	TS-D	Fill 1: ARG (90)	S	0.75	CL	0.33	0.43	0.58	57	
	00053-00001	S116 / Air / Clear (5mm/5mm) 19mm IG	VY/NA	2	0.076(2)	0.354	TS-D	Fill 1: AIR (100)	N		CL	0.35	0.46	0.64	50	
	00053-00002	S116 / Air / Clear (5mm/5mm) 19mm IG	VY/NA	2	0.076(2)	0.354	TS-D	Fill 1: AIR (100)	S	0.75	CL	0.35	0.42	0.57	50	
	00054-00001	S116 / Air / Clear (5mm/5mm) 19mm IG	VY/NA	2	0.076(2)	0.354	TS-D	Fill 1: AIR (100)	G	0.75	CL	0.38	0.42	0.57	50	
	00054-00002	S116 / Air / Clear (5mm/5mm) 19mm IG	VY/NA	2	0.076(2)	0.354	TS-D	Fill 1: AIR (100)	S	0.75	CL	0.38	0.42	0.57	50	
	00055-00001	S116 / ARG90 / Clear (5mm/5mm) 19mm IG	VY/NA	2	0.076(2)	0.354	TS-D	Fill 1: ARG (90)	N		CL	0.30	0.46	0.64	54	
	00055-00002	S116 / ARG90 / Clear (5mm/5mm) 19mm IG	VY/NA	2	0.076(2)	0.354	TS-D	Fill 1: ARG (90)	S	0.75	CL	0.30	0.41	0.57	54	
	00056-00001	S116 / ARG90 / Clear (5mm/5mm) 19mm IG	VY/NA	2	0.076(2)	0.354	TS-D	Fill 1: ARG (90)	G	0.75	CL	0.34	0.41	0.57	54	
	00056-00002	S116 / ARG90 / Clear (5mm/5mm) 19mm IG	VY/NA	2	0.076(2)	0.354	TS-D	Fill 1: ARG (90)	S	0.75	CL	0.34	0.41	0.57	54	
	00057-00001	Clear / Air / Clear (3mm/3mm) 18mm IG	VY/NA	2		0.472	TS-D	Fill 1: AIR (100)	N		CL	0.45	0.64	0.67	43	
	00057-00002	Clear / Air / Clear (3mm/3mm) 18mm IG	VY/NA	2		0.472	TS-D	Fill 1: AIR (100)	S	0.75	CL	0.45	0.57	0.60	43	
	00058-00001	Clear / Air / Clear (3mm/3mm) 18mm IG	VY/NA	2		0.472	TS-D	Fill 1: AIR (100)	G	0.75	CL	0.49	0.57	0.60	42	
	00058-00002	Clear / Air / Clear (3mm/3mm) 18mm IG	VY/NA	2		0.472	TS-D	Fill 1: AIR (100)	S	0.75	CL	0.49	0.57	0.60	42	
	00059-00001	Clear / Air / Clear (5mm/5mm) 19mm IG	VY/NA	2		0.354	TS-D	Fill 1: AIR (100)	N		CL	0.47	0.60	0.65	42	
	00059-00002	Clear / Air / Clear (5mm/5mm) 19mm IG	VY/NA	2		0.354	TS-D	Fill 1: AIR (100)	S	0.75	CL	0.47	0.54	0.58	42	
	00060-00001	Clear / Air / Clear (5mm/5mm) 19mm IG	VY/NA	2		0.354	TS-D	Fill 1: AIR (100)	G	0.75	CL	0.49	0.54	0.58	42	

NFRC Product Certification Authorization Report



Manufacturer: SourcePoint Doors and Windows LLC
Street: 4363 Northeast Expressway
City/State/Zip: Atlanta, Georgia
Print Date: 10/06/2026

Product Series: 82 Series Fixed Window
Product Type: FIXD
Air Leakage:

Simulation Lab: SATI
Sim. Report #: S3851.01-116-45 R0
Sim. Report Date: 05/15/2025
Test Date: 03/07/2026

Initial Cert. Date: 06/08/2026
Re-Certification Date:
Revised Date: 01/01/1970
Expiration Date: 03/07/2031

CPD Number: SUU-M-4						IA: National Accreditation And Management Institute									
Status	Product Num.	Manufacturer Code	Frame/ Sash	Glaz Lyrs	Low-E (Surface)	Gap Width(s)	Spacer	Gap Fill	Grids	Dividers	Tint	U-Factor	SHGC	VT	Cond. Res
	00060-00002	Clear / Air / Clear (5mm/5mm) 19mm IG	VY/NA	2		0.354	TS-D	Fill 1: AIR (100)	S	0.75	CL	0.49	0.54	0.58	42
	00061-00001	S116 / ARG90 / S116 (3mm/3mm) 18mm IG	VY/NA	2	0.057(2), 0.057(3)	0.472	TS-D	Fill 1: ARG (90)	N		CL	0.27	0.44	0.64	59
	00061-00002	S116 / ARG90 / S116 (3mm/3mm) 18mm IG	VY/NA	2	0.057(2), 0.057(3)	0.472	TS-D	Fill 1: ARG (90)	S	0.75	CL	0.27	0.40	0.57	59
	00062-00001	S116 / ARG90 / S116 (3mm/3mm) 18mm IG	VY/NA	2	0.057(2), 0.057(3)	0.472	TS-D	Fill 1: ARG (90)	G	0.75	CL	0.32	0.40	0.57	58
	00062-00002	S116 / ARG90 / S116 (3mm/3mm) 18mm IG	VY/NA	2	0.057(2), 0.057(3)	0.472	TS-D	Fill 1: ARG (90)	S	0.75	CL	0.32	0.40	0.57	58
	00063-00001	S116 / ARG90 / S116 (5mm/5mm) 19mm IG	VY/NA	2	0.076(2), 0.076(3)	0.354	TS-D	Fill 1: ARG (90)	N		CL	0.29	0.43	0.63	55
	00063-00002	S116 / ARG90 / S116 (5mm/5mm) 19mm IG	VY/NA	2	0.076(2), 0.076(3)	0.354	TS-D	Fill 1: ARG (90)	S	0.75	CL	0.29	0.39	0.56	55
	00064-00001	S116 / ARG90 / S116 (5mm/5mm) 19mm IG	VY/NA	2	0.076(2), 0.076(3)	0.354	TS-D	Fill 1: ARG (90)	G	0.75	CL	0.32	0.39	0.56	55
	00064-00002	S116 / ARG90 / S116 (5mm/5mm) 19mm IG	VY/NA	2	0.076(2), 0.076(3)	0.354	TS-D	Fill 1: ARG (90)	S	0.75	CL	0.32	0.39	0.56	55

Baseline Information

Test Lab	Test Date	Test Size	Tested U-Value	Standard U-Value	Test Report Number
TATI	03/07/2026	1200mm x 1499mm	0.318	0.313	S3852.01-116-46

Comments:

I hereby certify that all requirements for NFRC Certification Authorization have been met and that the above information is true and correct, to the best of my knowledge.

Authorized IA
Signature: _____