NFRC Product Certification Authorization Report

Manufacturer: SourcePoint Doors and Windows LLC
Product Series: 82 Series Single Hung
Simulation Lab: SATI
Initial Cert. Date: 06/08/2026

Street: 4363 Northeast Expressway
Product Type: VSSH
Sim. Report #: S3853.01-116-45 R0
Re-Certification Date:

City/State/Zip: Atlanta, Georgia
Air Leakage:
Sim. Report Date: 05/15/2025
Revised Date: 01/01/1970

Print Date: 10/06/2026
Test Date: 11/19/2025
Expiration Date: 11/19/2030

CPD Number: SUU-M-6 — **IA: National Accreditation And Management Institute**

Status	Product Num.	Manufacturer Code	Frame/ Sash	Glaz Lyrs	Low-E (Surface)	Gap Width(s)	Spacer	Gap Fill	Grids	Dividers	Tint	U-Factor	SHGC	VT	Cond. Res
	00001-00001	S116 / Air / Clear (3mm/3mm) 22mm IG	VY/VY	2	0.057(2)	0.630	A1-D	Fill 1: AIR (100)	N		CL	0.34	0.46	0.63	49
	00001-00002	S116 / Air / Clear (3mm/3mm) 22mm IG	VY/VY	2	0.057(2)	0.630	A1-D	Fill 1: AIR (100)	S	0.75	CL	0.34	0.41	0.56	49
	00002-00001	S116 / Air / Clear (3mm/3mm) 22mm IG	VY/VY	2	0.057(2)	0.630	A1-D	Fill 1: AIR (100)	G	0.75	CL	0.36	0.41	0.56	49
	00002-00002	S116 / Air / Clear (3mm/3mm) 22mm IG	VY/VY	2	0.057(2)	0.630	A1-D	Fill 1: AIR (100)	S	0.75	CL	0.36	0.41	0.56	49
	00003-00001	S116 / ARG90 / Clear (3mm/3mm) 22mm IG	VY/VY	2	0.057(2)	0.630	A1-D	Fill 1: ARG (90)	N		CL	0.31	0.46	0.63	51
	00003-00002	S116 / ARG90 / Clear (3mm/3mm) 22mm IG	VY/VY	2	0.057(2)	0.630	A1-D	Fill 1: ARG (90)	S	0.75	CL	0.31	0.41	0.56	51
	00004-00001	S116 / ARG90 / Clear (3mm/3mm) 22mm IG	VY/VY	2	0.057(2)	0.630	A1-D	Fill 1: ARG (90)	G	0.75	CL	0.32	0.41	0.56	51
	00004-00002	S116 / ARG90 / Clear (3mm/3mm) 22mm IG	VY/VY	2	0.057(2)	0.630	A1-D	Fill 1: ARG (90)	S	0.75	CL	0.32	0.41	0.56	51
	00005-00001	S116 / Air / Clear (5mm/5mm) 22mm IG	VY/VY	2	0.076(2)	0.472	A1-D	Fill 1: AIR (100)	N		CL	0.34	0.44	0.61	47
	00005-00002	S116 / Air / Clear (5mm/5mm) 22mm IG	VY/VY	2	0.076(2)	0.472	A1-D	Fill 1: AIR (100)	S	0.75	CL	0.34	0.40	0.55	47
	00006-00001	S116 / Air / Clear (5mm/5mm) 22mm IG	VY/VY	2	0.076(2)	0.472	A1-D	Fill 1: AIR (100)	G	0.75	CL	0.39	0.40	0.55	47
	00006-00002	S116 / Air / Clear (5mm/5mm) 22mm IG	VY/VY	2	0.076(2)	0.472	A1-D	Fill 1: AIR (100)	S	0.75	CL	0.39	0.40	0.55	47
	00007-00001	S116 / ARG90 / Clear (5mm/5mm) 22mm IG	VY/VY	2	0.076(2)	0.472	A1-D	Fill 1: ARG (90)	N		CL	0.31	0.44	0.61	49
	00007-00002	S116 / ARG90 / Clear (5mm/5mm) 22mm IG	VY/VY	2	0.076(2)	0.472	A1-D	Fill 1: ARG (90)	S	0.75	CL	0.31	0.40	0.55	49
	00008-00001	S116 / ARG90 / Clear (5mm/5mm) 22mm IG	VY/VY	2	0.076(2)	0.472	A1-D	Fill 1: ARG (90)	G	0.75	CL	0.35	0.40	0.55	49
	00008-00002	S116 / ARG90 / Clear (5mm/5mm) 22mm IG	VY/VY	2	0.076(2)	0.472	A1-D	Fill 1: ARG (90)	S	0.75	CL	0.35	0.40	0.55	49
	00009-00001	Clear / Air / Clear (3mm/3mm) 22mm IG	VY/VY	2		0.630	A1-D	Fill 1: AIR (100)	N		CL	0.46	0.61	0.64	41
	00009-00002	Clear / Air / Clear (3mm/3mm) 22mm IG	VY/VY	2		0.630	A1-D	Fill 1: AIR (100)	S	0.75	CL	0.46	0.55	0.57	41
	00010-00001	Clear / Air / Clear (3mm/3mm) 22mm IG	VY/VY	2		0.630	A1-D	Fill 1: AIR (100)	G	0.75	CL	0.47	0.55	0.57	41
	00010-00002	Clear / Air / Clear (3mm/3mm) 22mm IG	VY/VY	2		0.630	A1-D	Fill 1: AIR (100)	S	0.75	CL	0.47	0.55	0.57	41

NFRC Product Certification Authorization Report

Manufacturer: SourcePoint Doors and Windows LLC
Product Series: 82 Series Single Hung
Simulation Lab: SATI
Initial Cert. Date: 06/08/2026

Street: 4363 Northeast Expressway
Product Type: VSSH
Sim. Report #: S3853.01-116-45 R0
Re-Certification Date:

City/State/Zip: Atlanta, Georgia
Air Leakage:
Sim. Report Date: 05/15/2025
Revised Date: 01/01/1970

Print Date: 10/06/2026
Test Date: 11/19/2025
Expiration Date: 11/19/2030

CPD Number: SUU-M-6 — **IA: National Accreditation And Management Institute**

Status	Product Num.	Manufacturer Code	Frame/ Sash	Glaz Lyrs	Low-E (Surface)	Gap Width(s)	Spacer	Gap Fill	Grids	Dividers	Tint	U-Factor	SHGC	VT	Cond. Res
	00011-00001	Clear / Air / Clear (5mm/5mm) 22mm IG	VY/VY	2		0.472	A1-D	Fill 1: AIR (100)	N		CL	0.46	0.58	0.62	40
	00011-00002	Clear / Air / Clear (5mm/5mm) 22mm IG	VY/VY	2		0.472	A1-D	Fill 1: AIR (100)	S	0.75	CL	0.46	0.52	0.56	40
	00012-00001	Clear / Air / Clear (5mm/5mm) 22mm IG	VY/VY	2		0.472	A1-D	Fill 1: AIR (100)	G	0.75	CL	0.50	0.52	0.56	40
	00012-00002	Clear / Air / Clear (5mm/5mm) 22mm IG	VY/VY	2		0.472	A1-D	Fill 1: AIR (100)	S	0.75	CL	0.50	0.52	0.56	40
	00013-00001	S116 / ARG90 / S116 (3mm/3mm) 22mm IG	VY/VY	2	0.057(2), 0.057(3)	0.630	A1-D	Fill 1: ARG (90)	N		CL	0.30	0.42	0.61	52
	00013-00002	S116 / ARG90 / S116 (3mm/3mm) 22mm IG	VY/VY	2	0.057(2), 0.057(3)	0.630	A1-D	Fill 1: ARG (90)	S	0.75	CL	0.30	0.38	0.55	52
	00014-00001	S116 / ARG90 / S116 (3mm/3mm) 22mm IG	VY/VY	2	0.057(2), 0.057(3)	0.630	A1-D	Fill 1: ARG (90)	G	0.75	CL	0.31	0.38	0.55	52
	00014-00002	S116 / ARG90 / S116 (3mm/3mm) 22mm IG	VY/VY	2	0.057(2), 0.057(3)	0.630	A1-D	Fill 1: ARG (90)	S	0.75	CL	0.31	0.38	0.55	52
	00015-00001	S116 / ARG90 / S116 (5mm/5mm) 22mm IG	VY/VY	2	0.076(2), 0.076(3)	0.472	A1-D	Fill 1: ARG (90)	N		CL	0.30	0.41	0.60	50
	00015-00002	S116 / ARG90 / S116 (5mm/5mm) 22mm IG	VY/VY	2	0.076(2), 0.076(3)	0.472	A1-D	Fill 1: ARG (90)	S	0.75	CL	0.30	0.37	0.54	50
	00016-00001	S116 / ARG90 / S116 (5mm/5mm) 22mm IG	VY/VY	2	0.076(2), 0.076(3)	0.472	A1-D	Fill 1: ARG (90)	G	0.75	CL	0.34	0.37	0.54	50
	00016-00002	S116 / ARG90 / S116 (5mm/5mm) 22mm IG	VY/VY	2	0.076(2), 0.076(3)	0.472	A1-D	Fill 1: ARG (90)	S	0.75	CL	0.34	0.37	0.54	50
	00017-00001	S116 / Air / Clear (3mm/3mm) 18mm IG	VY/VY	2	0.057(2)	0.472	A1-D	Fill 1: AIR (100)	N		CL	0.33	0.46	0.63	48
	00017-00002	S116 / Air / Clear (3mm/3mm) 18mm IG	VY/VY	2	0.057(2)	0.472	A1-D	Fill 1: AIR (100)	S	0.75	CL	0.33	0.41	0.56	48
	00018-00001	S116 / Air / Clear (3mm/3mm) 18mm IG	VY/VY	2	0.057(2)	0.472	A1-D	Fill 1: AIR (100)	G	0.75	CL	0.38	0.41	0.56	48
	00018-00002	S116 / Air / Clear (3mm/3mm) 18mm IG	VY/VY	2	0.057(2)	0.472	A1-D	Fill 1: AIR (100)	S	0.75	CL	0.38	0.41	0.56	48
	00019-00001	S116 / ARG90 / Clear (3mm/3mm) 18mm IG	VY/VY	2	0.057(2)	0.472	A1-D	Fill 1: ARG (90)	N		CL	0.30	0.46	0.63	50
	00019-00002	S116 / ARG90 / Clear (3mm/3mm) 18mm IG	VY/VY	2	0.057(2)	0.472	A1-D	Fill 1: ARG (90)	S	0.75	CL	0.30	0.41	0.56	50
	00020-00001	S116 / ARG90 / Clear (3mm/3mm) 18mm IG	VY/VY	2	0.057(2)	0.472	A1-D	Fill 1: ARG (90)	G	0.75	CL	0.35	0.41	0.56	50

NFRC Product Certification Authorization Report

Manufacturer: SourcePoint Doors and Windows LLC
Product Series: 82 Series Single Hung
Simulation Lab: SATI
Initial Cert. Date: 06/08/2026

Street: 4363 Northeast Expressway
Product Type: VSSH
Sim. Report #: S3853.01-116-45 R0
Re-Certification Date:

City/State/Zip: Atlanta, Georgia
Air Leakage:
Sim. Report Date: 05/15/2025
Revised Date: 01/01/1970

Print Date: 10/06/2026
Test Date: 11/19/2025
Expiration Date: 11/19/2030

CPD Number: SUU-M-6 **IA: National Accreditation And Management Institute**

Status	Product Num.	Manufacturer Code	Frame/ Sash	Glaz Lyrs	Low-E (Surface)	Gap Width(s)	Spacer	Gap Fill	Grids	Dividers	Tint	U-Factor	SHGC	VT	Cond. Res
	00020-00002	S116 / ARG90 / Clear (3mm/3mm) 18mm IG	VY/VY	2	0.057(2)	0.472	A1-D	Fill 1: ARG (90)	S	0.75	CL	0.35	0.41	0.56	50
	00021-00001	S116 / Air / Clear (5mm/5mm) 19mm IG	VY/VY	2	0.076(2)	0.354	A1-D	Fill 1: AIR (100)	N		CL	0.36	0.44	0.61	45
	00021-00002	S116 / Air / Clear (5mm/5mm) 19mm IG	VY/VY	2	0.076(2)	0.354	A1-D	Fill 1: AIR (100)	S	0.75	CL	0.36	0.40	0.55	45
	00022-00001	S116 / Air / Clear (5mm/5mm) 19mm IG	VY/VY	2	0.076(2)	0.354	A1-D	Fill 1: AIR (100)	G	0.75	CL	0.40	0.40	0.55	45
	00022-00002	S116 / Air / Clear (5mm/5mm) 19mm IG	VY/VY	2	0.076(2)	0.354	A1-D	Fill 1: AIR (100)	S	0.75	CL	0.40	0.40	0.55	45
	00023-00001	S116 / ARG90 / Clear (5mm/5mm) 19mm IG	VY/VY	2	0.076(2)	0.354	A1-D	Fill 1: ARG (90)	N		CL	0.32	0.44	0.61	48
	00023-00002	S116 / ARG90 / Clear (5mm/5mm) 19mm IG	VY/VY	2	0.076(2)	0.354	A1-D	Fill 1: ARG (90)	S	0.75	CL	0.32	0.40	0.55	48
	00024-00001	S116 / ARG90 / Clear (5mm/5mm) 19mm IG	VY/VY	2	0.076(2)	0.354	A1-D	Fill 1: ARG (90)	G	0.75	CL	0.35	0.40	0.55	48
	00024-00002	S116 / ARG90 / Clear (5mm/5mm) 19mm IG	VY/VY	2	0.076(2)	0.354	A1-D	Fill 1: ARG (90)	S	0.75	CL	0.35	0.40	0.55	48
	00025-00001	Clear / Air / Clear (3mm/3mm) 18mm IG	VY/VY	2		0.472	A1-D	Fill 1: AIR (100)	N		CL	0.46	0.61	0.64	40
	00025-00002	Clear / Air / Clear (3mm/3mm) 18mm IG	VY/VY	2		0.472	A1-D	Fill 1: AIR (100)	S	0.75	CL	0.46	0.55	0.57	40
	00026-00001	Clear / Air / Clear (3mm/3mm) 18mm IG	VY/VY	2		0.472	A1-D	Fill 1: AIR (100)	G	0.75	CL	0.50	0.55	0.57	40
	00026-00002	Clear / Air / Clear (3mm/3mm) 18mm IG	VY/VY	2		0.472	A1-D	Fill 1: AIR (100)	S	0.75	CL	0.50	0.55	0.57	40
	00027-00001	Clear / Air / Clear (5mm/5mm) 19mm IG	VY/VY	2		0.354	A1-D	Fill 1: AIR (100)	N		CL	0.48	0.58	0.62	38
	00027-00002	Clear / Air / Clear (5mm/5mm) 19mm IG	VY/VY	2		0.354	A1-D	Fill 1: AIR (100)	S	0.75	CL	0.48	0.52	0.56	38
	00028-00001	Clear / Air / Clear (5mm/5mm) 19mm IG	VY/VY	2		0.354	A1-D	Fill 1: AIR (100)	G	0.75	CL	0.50	0.52	0.56	38
	00028-00002	Clear / Air / Clear (5mm/5mm) 19mm IG	VY/VY	2		0.354	A1-D	Fill 1: AIR (100)	S	0.75	CL	0.50	0.52	0.56	38
	00029-00001	S116 / ARG90 / S116 (3mm/3mm) 18mm IG	VY/VY	2	0.057(2), 0.057(3)	0.472	A1-D	Fill 1: ARG (90)	N		CL	0.29	0.42	0.61	51
	00029-00002	S116 / ARG90 / S116 (3mm/3mm) 18mm IG	VY/VY	2	0.057(2), 0.057(3)	0.472	A1-D	Fill 1: ARG (90)	S	0.75	CL	0.29	0.38	0.55	51
	00030-00001	S116 / ARG90 / S116 (3mm/3mm) 18mm IG	VY/VY	2	0.057(2), 0.057(3)	0.472	A1-D	Fill 1: ARG (90)	G	0.75	CL	0.34	0.38	0.55	51

NFRC Product Certification Authorization Report

Manufacturer: SourcePoint Doors and Windows LLC
Product Series: 82 Series Single Hung
Simulation Lab: SATI
Initial Cert. Date: 06/08/2026

Street: 4363 Northeast Expressway
Product Type: VSSH
Sim. Report #: S3853.01-116-45 R0
Re-Certification Date:

City/State/Zip: Atlanta, Georgia
Air Leakage:
Sim. Report Date: 05/15/2025
Revised Date: 01/01/1970

Print Date: 10/06/2026
Test Date: 11/19/2025
Expiration Date: 11/19/2030

CPD Number: SUU-M-6 | **IA: National Accreditation And Management Institute**

Status	Product Num.	Manufacturer Code	Frame/ Sash	Glaz Lyrs	Low-E (Surface)	Gap Width(s)	Spacer	Gap Fill	Grids	Dividers	Tint	U-Factor	SHGC	VT	Cond. Res
	00030-00002	S116 / ARG90 / S116 (3mm/3mm) 18mm IG	VY/VY	2	0.057(2), 0.057(3)	0.472	A1-D	Fill 1: ARG (90)	S	0.75	CL	0.34	0.38	0.55	51
	00031-00001	S116 / ARG90 / S116 (5mm/5mm) 19mm IG	VY/VY	2	0.076(2), 0.076(3)	0.354	A1-D	Fill 1: ARG (90)	N		CL	0.31	0.41	0.60	49
	00031-00002	S116 / ARG90 / S116 (5mm/5mm) 19mm IG	VY/VY	2	0.076(2), 0.076(3)	0.354	A1-D	Fill 1: ARG (90)	S	0.75	CL	0.31	0.37	0.54	49
	00032-00001	S116 / ARG90 / S116 (5mm/5mm) 19mm IG	VY/VY	2	0.076(2), 0.076(3)	0.354	A1-D	Fill 1: ARG (90)	G	0.75	CL	0.34	0.37	0.54	49
	00032-00002	S116 / ARG90 / S116 (5mm/5mm) 19mm IG	VY/VY	2	0.076(2), 0.076(3)	0.354	A1-D	Fill 1: ARG (90)	S	0.75	CL	0.34	0.37	0.54	49
	00033-00001	S116 / Air / Clear (3mm/3mm) 22mm IG	VY/VY	2	0.057(2)	0.630	TS-D	Fill 1: AIR (100)	N		CL	0.32	0.46	0.63	55
	00033-00002	S116 / Air / Clear (3mm/3mm) 22mm IG	VY/VY	2	0.057(2)	0.630	TS-D	Fill 1: AIR (100)	S	0.75	CL	0.32	0.41	0.56	55
	00034-00001	S116 / Air / Clear (3mm/3mm) 22mm IG	VY/VY	2	0.057(2)	0.630	TS-D	Fill 1: AIR (100)	G	0.75	CL	0.34	0.41	0.56	55
	00034-00002	S116 / Air / Clear (3mm/3mm) 22mm IG	VY/VY	2	0.057(2)	0.630	TS-D	Fill 1: AIR (100)	S	0.75	CL	0.34	0.41	0.56	55
	00035-00001	S116 / ARG90 / Clear (3mm/3mm) 22mm IG	VY/VY	2	0.057(2)	0.630	TS-D	Fill 1: ARG (90)	N		CL	0.28	0.46	0.63	58
	00035-00002	S116 / ARG90 / Clear (3mm/3mm) 22mm IG	VY/VY	2	0.057(2)	0.630	TS-D	Fill 1: ARG (90)	S	0.75	CL	0.28	0.41	0.56	58
	00036-00001	S116 / ARG90 / Clear (3mm/3mm) 22mm IG	VY/VY	2	0.057(2)	0.630	TS-D	Fill 1: ARG (90)	G	0.75	CL	0.30	0.41	0.56	58
	00036-00002	S116 / ARG90 / Clear (3mm/3mm) 22mm IG	VY/VY	2	0.057(2)	0.630	TS-D	Fill 1: ARG (90)	S	0.75	CL	0.30	0.41	0.56	58
	00037-00001	S116 / Air / Clear (5mm/5mm) 22mm IG	VY/VY	2	0.076(2)	0.472	TS-D	Fill 1: AIR (100)	N		CL	0.32	0.44	0.61	52
	00037-00002	S116 / Air / Clear (5mm/5mm) 22mm IG	VY/VY	2	0.076(2)	0.472	TS-D	Fill 1: AIR (100)	S	0.75	CL	0.32	0.40	0.55	52
	00038-00001	S116 / Air / Clear (5mm/5mm) 22mm IG	VY/VY	2	0.076(2)	0.472	TS-D	Fill 1: AIR (100)	G	0.75	CL	0.37	0.40	0.55	52
	00038-00002	S116 / Air / Clear (5mm/5mm) 22mm IG	VY/VY	2	0.076(2)	0.472	TS-D	Fill 1: AIR (100)	S	0.75	CL	0.37	0.40	0.55	52
	00039-00001	S116 / ARG90 / Clear (5mm/5mm) 22mm IG	VY/VY	2	0.076(2)	0.472	TS-D	Fill 1: ARG (90)	N		CL	0.29	0.44	0.61	55
	00039-00002	S116 / ARG90 / Clear (5mm/5mm) 22mm IG	VY/VY	2	0.076(2)	0.472	TS-D	Fill 1: ARG (90)	S	0.75	CL	0.29	0.40	0.55	55

NFRC Product Certification Authorization Report

Manufacturer: SourcePoint Doors and Windows LLC
Product Series: 82 Series Single Hung
Simulation Lab: SATI
Initial Cert. Date: 06/08/2026

Street: 4363 Northeast Expressway
Product Type: VSSH
Sim. Report #: S3853.01-116-45 R0
Re-Certification Date:

City/State/Zip: Atlanta, Georgia
Air Leakage:
Sim. Report Date: 05/15/2025
Revised Date: 01/01/1970

Print Date: 10/06/2026
Test Date: 11/19/2025
Expiration Date: 11/19/2030

CPD Number: SUU-M-6 **IA: National Accreditation And Management Institute**

Status	Product Num.	Manufacturer Code	Frame/ Sash	Glaz Lyrs	Low-E (Surface)	Gap Width(s)	Spacer	Gap Fill	Grids	Dividers	Tint	U-Factor	SHGC	VT	Cond. Res
	00040-00001	S116 / ARG90 / Clear (5mm/5mm) 22mm IG	VY/VY	2	0.076(2)	0.472	TS-D	Fill 1: ARG (90)	G	0.75	CL	0.33	0.40	0.55	55
	00040-00002	S116 / ARG90 / Clear (5mm/5mm) 22mm IG	VY/VY	2	0.076(2)	0.472	TS-D	Fill 1: ARG (90)	S	0.75	CL	0.33	0.40	0.55	55
	00041-00001	Clear / Air / Clear (3mm/3mm) 22mm IG	VY/VY	2		0.630	TS-D	Fill 1: AIR (100)	N		CL	0.45	0.61	0.64	44
	00041-00002	Clear / Air / Clear (3mm/3mm) 22mm IG	VY/VY	2		0.630	TS-D	Fill 1: AIR (100)	S	0.75	CL	0.45	0.55	0.57	44
	00042-00001	Clear / Air / Clear (3mm/3mm) 22mm IG	VY/VY	2		0.630	TS-D	Fill 1: AIR (100)	G	0.75	CL	0.46	0.55	0.57	44
	00042-00002	Clear / Air / Clear (3mm/3mm) 22mm IG	VY/VY	2		0.630	TS-D	Fill 1: AIR (100)	S	0.75	CL	0.46	0.55	0.57	44
	00043-00001	Clear / Air / Clear (5mm/5mm) 22mm IG	VY/VY	2		0.472	TS-D	Fill 1: AIR (100)	N		CL	0.45	0.58	0.62	43
	00043-00002	Clear / Air / Clear (5mm/5mm) 22mm IG	VY/VY	2		0.472	TS-D	Fill 1: AIR (100)	S	0.75	CL	0.45	0.52	0.56	43
	00044-00001	Clear / Air / Clear (5mm/5mm) 22mm IG	VY/VY	2		0.472	TS-D	Fill 1: AIR (100)	G	0.75	CL	0.48	0.52	0.56	42
	00044-00002	Clear / Air / Clear (5mm/5mm) 22mm IG	VY/VY	2		0.472	TS-D	Fill 1: AIR (100)	S	0.75	CL	0.48	0.52	0.56	42
	00045-00001	S116 / ARG90 / S116 (3mm/3mm) 22mm IG	VY/VY	2	0.057(2), 0.057(3)	0.630	TS-D	Fill 1: ARG (90)	N		CL	0.28	0.42	0.61	59
	00045-00002	S116 / ARG90 / S116 (3mm/3mm) 22mm IG	VY/VY	2	0.057(2), 0.057(3)	0.630	TS-D	Fill 1: ARG (90)	S	0.75	CL	0.28	0.38	0.55	59
	00046-00001	S116 / ARG90 / S116 (3mm/3mm) 22mm IG	VY/VY	2	0.057(2), 0.057(3)	0.630	TS-D	Fill 1: ARG (90)	G	0.75	CL	0.29	0.38	0.55	59
	00046-00002	S116 / ARG90 / S116 (3mm/3mm) 22mm IG	VY/VY	2	0.057(2), 0.057(3)	0.630	TS-D	Fill 1: ARG (90)	S	0.75	CL	0.29	0.38	0.55	59
	00047-00001	S116 / ARG90 / S116 (5mm/5mm) 22mm IG	VY/VY	2	0.076(2), 0.076(3)	0.472	TS-D	Fill 1: ARG (90)	N		CL	0.28	0.41	0.60	56
	00047-00002	S116 / ARG90 / S116 (5mm/5mm) 22mm IG	VY/VY	2	0.076(2), 0.076(3)	0.472	TS-D	Fill 1: ARG (90)	S	0.75	CL	0.28	0.37	0.54	56
	00048-00001	S116 / ARG90 / S116 (5mm/5mm) 22mm IG	VY/VY	2	0.076(2), 0.076(3)	0.472	TS-D	Fill 1: ARG (90)	G	0.75	CL	0.32	0.37	0.54	56
	00048-00002	S116 / ARG90 / S116 (5mm/5mm) 22mm IG	VY/VY	2	0.076(2), 0.076(3)	0.472	TS-D	Fill 1: ARG (90)	S	0.75	CL	0.32	0.37	0.54	56
	00049-00001	S116 / Air / Clear (3mm/3mm) 18mm IG	VY/VY	2	0.057(2)	0.472	TS-D	Fill 1: AIR (100)	N		CL	0.31	0.46	0.63	53
	00049-00002	S116 / Air / Clear (3mm/3mm) 18mm IG	VY/VY	2	0.057(2)	0.472	TS-D	Fill 1: AIR (100)	S	0.75	CL	0.31	0.41	0.56	53

NFRC Product Certification Authorization Report

Manufacturer: SourcePoint Doors and Windows LLC
Product Series: 82 Series Single Hung
Simulation Lab: SATI
Initial Cert. Date: 06/08/2026

Street: 4363 Northeast Expressway
Product Type: VSSH
Sim. Report #: S3853.01-116-45 R0
Re-Certification Date:

City/State/Zip: Atlanta, Georgia
Air Leakage:
Sim. Report Date: 05/15/2025
Revised Date: 01/01/1970

Print Date: 10/06/2026
Test Date: 11/19/2025
Expiration Date: 11/19/2030

CPD Number: SUU-M-6 **IA: National Accreditation And Management Institute**

Status	Product Num.	Manufacturer Code	Frame/ Sash	Glaz Lyrs	Low-E (Surface)	Gap Width(s)	Spacer	Gap Fill	Grids	Dividers	Tint	U-Factor	SHGC	VT	Cond. Res
	00050-00001	S116 / Air / Clear (3mm/3mm) 18mm IG	VY/VY	2	0.057(2)	0.472	TS-D	Fill 1: AIR (100)	G	0.75	CL	0.37	0.41	0.56	52
	00050-00002	S116 / Air / Clear (3mm/3mm) 18mm IG	VY/VY	2	0.057(2)	0.472	TS-D	Fill 1: AIR (100)	S	0.75	CL	0.37	0.41	0.56	52
	00051-00001	S116 / ARG90 / Clear (3mm/3mm) 18mm IG	VY/VY	2	0.057(2)	0.472	TS-D	Fill 1: ARG (90)	N		CL	0.28	0.46	0.63	56
	00051-00002	S116 / ARG90 / Clear (3mm/3mm) 18mm IG	VY/VY	2	0.057(2)	0.472	TS-D	Fill 1: ARG (90)	S	0.75	CL	0.28	0.41	0.56	56
	00052-00001	S116 / ARG90 / Clear (3mm/3mm) 18mm IG	VY/VY	2	0.057(2)	0.472	TS-D	Fill 1: ARG (90)	G	0.75	CL	0.33	0.41	0.56	56
	00052-00002	S116 / ARG90 / Clear (3mm/3mm) 18mm IG	VY/VY	2	0.057(2)	0.472	TS-D	Fill 1: ARG (90)	S	0.75	CL	0.33	0.41	0.56	56
	00053-00001	S116 / Air / Clear (5mm/5mm) 19mm IG	VY/VY	2	0.076(2)	0.354	TS-D	Fill 1: AIR (100)	N		CL	0.35	0.44	0.61	49
	00053-00002	S116 / Air / Clear (5mm/5mm) 19mm IG	VY/VY	2	0.076(2)	0.354	TS-D	Fill 1: AIR (100)	S	0.75	CL	0.35	0.40	0.55	49
	00054-00001	S116 / Air / Clear (5mm/5mm) 19mm IG	VY/VY	2	0.076(2)	0.354	TS-D	Fill 1: AIR (100)	G	0.75	CL	0.38	0.40	0.55	49
	00054-00002	S116 / Air / Clear (5mm/5mm) 19mm IG	VY/VY	2	0.076(2)	0.354	TS-D	Fill 1: AIR (100)	S	0.75	CL	0.38	0.40	0.55	49
	00055-00001	S116 / ARG90 / Clear (5mm/5mm) 19mm IG	VY/VY	2	0.076(2)	0.354	TS-D	Fill 1: ARG (90)	N		CL	0.30	0.44	0.61	53
	00055-00002	S116 / ARG90 / Clear (5mm/5mm) 19mm IG	VY/VY	2	0.076(2)	0.354	TS-D	Fill 1: ARG (90)	S	0.75	CL	0.30	0.40	0.55	53
	00056-00001	S116 / ARG90 / Clear (5mm/5mm) 19mm IG	VY/VY	2	0.076(2)	0.354	TS-D	Fill 1: ARG (90)	G	0.75	CL	0.34	0.40	0.55	53
	00056-00002	S116 / ARG90 / Clear (5mm/5mm) 19mm IG	VY/VY	2	0.076(2)	0.354	TS-D	Fill 1: ARG (90)	S	0.75	CL	0.34	0.40	0.55	53
	00057-00001	Clear / Air / Clear (3mm/3mm) 18mm IG	VY/VY	2		0.472	TS-D	Fill 1: AIR (100)	N		CL	0.45	0.61	0.64	43
	00057-00002	Clear / Air / Clear (3mm/3mm) 18mm IG	VY/VY	2		0.472	TS-D	Fill 1: AIR (100)	S	0.75	CL	0.45	0.55	0.57	43
	00058-00001	Clear / Air / Clear (3mm/3mm) 18mm IG	VY/VY	2		0.472	TS-D	Fill 1: AIR (100)	G	0.75	CL	0.48	0.55	0.57	41
	00058-00002	Clear / Air / Clear (3mm/3mm) 18mm IG	VY/VY	2		0.472	TS-D	Fill 1: AIR (100)	S	0.75	CL	0.48	0.55	0.57	41
	00059-00001	Clear / Air / Clear (5mm/5mm) 19mm IG	VY/VY	2		0.354	TS-D	Fill 1: AIR (100)	N		CL	0.46	0.58	0.62	41
	00059-00002	Clear / Air / Clear (5mm/5mm) 19mm IG	VY/VY	2		0.354	TS-D	Fill 1: AIR (100)	S	0.75	CL	0.46	0.52	0.56	41
	00060-00001	Clear / Air / Clear (5mm/5mm) 19mm IG	VY/VY	2		0.354	TS-D	Fill 1: AIR (100)	G	0.75	CL	0.49	0.52	0.56	41

NFRC Product Certification Authorization Report

Manufacturer: SourcePoint Doors and Windows LLC
Product Series: 82 Series Single Hung
Simulation Lab: SATI
Initial Cert. Date: 06/08/2026

Street: 4363 Northeast Expressway
Product Type: VSSH
Sim. Report #: S3853.01-116-45 R0
Re-Certification Date:

City/State/Zip: Atlanta, Georgia
Air Leakage:
Sim. Report Date: 05/15/2025
Revised Date: 01/01/1970

Print Date: 10/06/2026
Test Date: 11/19/2025
Expiration Date: 11/19/2030

CPD Number: SUU-M-6 **IA: National Accreditation And Management Institute**

Status	Product Num.	Manufacturer Code	Frame/ Sash	Glaz Lyrs	Low-E (Surface)	Gap Width(s)	Spacer	Gap Fill	Grids	Dividers	Tint	U-Factor	SHGC	VT	Cond. Res
	00060-00002	Clear / Air / Clear (5mm/5mm) 19mm IG	VY/VY	2		0.354	TS-D	Fill 1: AIR (100)	S	0.75	CL	0.49	0.52	0.56	41
	00061-00001	S116 / ARG90 / S116 (3mm/3mm) 18mm IG	VY/VY	2	0.057(2), 0.057(3)	0.472	TS-D	Fill 1: ARG (90)	N		CL	0.27	0.42	0.61	57
	00061-00002	S116 / ARG90 / S116 (3mm/3mm) 18mm IG	VY/VY	2	0.057(2), 0.057(3)	0.472	TS-D	Fill 1: ARG (90)	S	0.75	CL	0.27	0.38	0.55	57
	00062-00001	S116 / ARG90 / S116 (3mm/3mm) 18mm IG	VY/VY	2	0.057(2), 0.057(3)	0.472	TS-D	Fill 1: ARG (90)	G	0.75	CL	0.32	0.38	0.55	57
	00062-00002	S116 / ARG90 / S116 (3mm/3mm) 18mm IG	VY/VY	2	0.057(2), 0.057(3)	0.472	TS-D	Fill 1: ARG (90)	S	0.75	CL	0.32	0.38	0.55	57
	00063-00001	S116 / ARG90 / S116 (5mm/5mm) 19mm IG	VY/VY	2	0.076(2), 0.076(3)	0.354	TS-D	Fill 1: ARG (90)	N		CL	0.29	0.41	0.60	54
	00063-00002	S116 / ARG90 / S116 (5mm/5mm) 19mm IG	VY/VY	2	0.076(2), 0.076(3)	0.354	TS-D	Fill 1: ARG (90)	S	0.75	CL	0.29	0.37	0.54	54
	00064-00001	S116 / ARG90 / S116 (5mm/5mm) 19mm IG	VY/VY	2	0.076(2), 0.076(3)	0.354	TS-D	Fill 1: ARG (90)	G	0.75	CL	0.33	0.37	0.54	54
	00064-00002	S116 / ARG90 / S116 (5mm/5mm) 19mm IG	VY/VY	2	0.076(2), 0.076(3)	0.354	TS-D	Fill 1: ARG (90)	S	0.75	CL	0.33	0.37	0.54	54

Baseline Information

Test Lab	Test Date	Test Size	Tested U-Value	Standard U-Value	Test Report Number
TATI	**11/19/2025**	1200mm x 1499mm	0.303	0.262	S3854.01-116-46

Comments:

I hereby certify that all requirements for NFRC Certification Authorization have been met and that the above information is true and correct, to the best of my knowledge.

Authorized IA Signature: _____